

JVC

SERVICE MANUAL


COLOUR TELEVISION

BASIC CHASSIS


CH

AV-34LS
AV-34LS_(-AU)
AV-34LH


AV-34LX
AV-34LX_(-A)
AV-3408TEE




RM-C352-1C
[AV-34LS]
[AV-34LS_(-AU)]




RM-C353-1C
[AV-34LH]



RM-C355-1C
[AV-3408TEE]



RM-C357-1C
[AV-34LX]
[AV-34LX_(-A)]



CONTENTS

■ SPECIFICATIONS	2
■ SAFETY PRECAUTIONS	3
■ FEATURES	4
■ FUNCTIONS	5
■ SPECIFIC SERVICE INSTRUCTIONS	6
★ OPERATING INSTRUCTIONS (APPENDIX)	1-1
■ SERVICE ADJUSTMENTS	14
★ STANDARD CIRCUIT DIAGRAM (APPENDIX)	2-1
■ PARTS LIST	37

SPECIFICATIONS

Items		Contents					
		AV-34LS	AV-34LS-AU	AV-34LH	AV-34LX	AV-34LX-A	AV-3408TEE
Dimensions (W × H × D)		89.8cm × 72.8cm × 57.9cm					
Mass		65.8kg					
TV RF System		B, G, I, D, K, M					
Colour System	TV Mode	PAL / SECAM / NTSC3.58 / NTSC4.43					
	VIDEO Mode	PAL / SECAM / NTSC3.58 / NTSC4.43					
Stereo System		A2/NICAM (B / G, I, D / K) System			Playback Only		
Teletext system FLOF(Fastext), WST(World Standard Text)		○		—		○	
Receiving Frequency	VHF (VL)	43.75MHz – 142.25MHz		(AU0 – S6)			
	VHF (VH)	142.28MHz – 428.75MHz		(S7 – S36)			
	UHF	428.78MHz – 865.75MHz		(S37 – CHINA 57)			
	CATV	● Cable TVs of Mid (X-Z, S1-S10) Super (S11-S20) & Hyper (S21-S41) bands receivable					
Intermediate Frequency	VIF Carrier	38.0MHz					
	SIF Carrier	31.5MHz (6.5MHz)					
		32.0MHz (6.0MHz)					
		32.5MHz (5.5MHz)					
		33.5MHz (4.5MHz)					
Colour Sub Carrier Frequency		PAL (4.43MHz), SECAM (4.40625MHz / 4.25MHz) NTSC (3.58MHz / 4.43MHz)					
Aerial Input Terminal		75Ω Unbalanced					
Power Input		AC110 – 240V, 50 / 60Hz					
Power Consumption		180W (Max.) / 110W (Avg.)		135W, 1.2A (at 220V)	180W (Max.) / 110W (Avg.)		
Picture Tube		Visible size : 68cm measured diagonally					
High Voltage		33kV +1/–1.5kV (at cut-off in service mode)					
Speaker		5 × 12cm Oval type ×2					
Audio Output		5W ×2					
Video / Audio Input (1 / 2 / 3)		Video(1,3) : 1Vp-p, 75Ω (RCA pin jack) Audio(1,2,3) : 500mVrms (-4dBs), High Impedance (RCA pin jack) S-Video (Input 1 Over) [Only for AV-34LS-AU] Y : 1Vp-p Positive (negative sync provided, when terminated with 75Ω) C : 0.286Vp-p (burst signal, when terminated with 75Ω) Component Input (Input 2) Y : 1Vp-p positive (negative sync provided, when terminated with 75Ω) Cb/CR : 0.7Vp-p 75Ω					
Video/Audio Output		1Vp-p, 75Ω (RCA pin jack) 500mVrms(-4dBs) Low impedance (400Hz when modulated 100%) (RCA pin jack)					
Headphone Jack		Stereo mini jack (3.5φ)					
Remote Control Unit		RM-C352-1C		RM-C353-1C	RM-C357-1C		RM-C355-1C
		(Battery size: AA/R06/UM-3 × 2)					

Design & specifications are subject to change without notice.

SAFETY PRECAUTIONS

1. The design of this product contains special hardware, many circuits and components specially for safety purposes. For continued protection, no changes should be made to the original design unless authorized in writing by the manufacturer. Replacement parts must be identical to those used in the original circuits. Service should be performed by qualified personnel only.
2. Alterations of the design or circuitry of the products should not be made. Any design alterations or additions will void the manufacturer's warranty and will further relieve the manufacturer of responsibility for personal injury or property damage resulting therefrom.
3. Many electrical and mechanical parts in the products have special safety-related characteristics. These characteristics are often not evident from visual inspection nor can the protection afforded by them necessarily be obtained by using replacement components rated for higher voltage, wattage, etc. Replacement parts which have these special safety characteristics are identified in the parts list of Service manual. **Electrical components having such features are identified by shading on the schematics and by (Δ) on the parts list in Service manual.** The use of a substitute replacement which does not have the same safety characteristics as the recommended replacement part shown in the parts list of Service manual may cause shock, fire, or other hazards.
4. **Don't short between the LIVE side ground and ISOLATED (NEUTRAL) side ground or EARTH side ground when repairing.**
Some model's power circuit is partly different in the GND. The difference of the GND is shown by the LIVE : (⊥) side GND, the ISOLATED (NEUTRAL) : (⊕) side GND and EARTH : (⊕) side GND. Don't short between the LIVE side GND and ISOLATED (NEUTRAL) side GND or EARTH side GND and never measure with a measuring apparatus (oscilloscope etc.) the LIVE side GND and ISOLATED (NEUTRAL) side GND or EARTH side GND at the same time.
If above note will not be kept, a fuse or any parts will be broken.
5. If any repair has been made to the chassis, it is recommended that the B1 setting should be checked or adjusted (See ADJUSTMENT OF B1 POWER SUPPLY).
6. The high voltage applied to the picture tube must conform with that specified in Service manual. Excessive high voltage can cause an increase in X-Ray emission, arcing and possible component damage, therefore operation under excessive high voltage conditions should be kept to a minimum, or should be prevented. If severe arcing occurs, remove the AC power immediately and determine the cause by visual inspection (incorrect installation, cracked or melted high voltage harness, poor soldering, etc.). To maintain the proper minimum level of soft X-Ray emission, components in the high voltage circuitry including the picture tube must be the exact replacements or alternatives approved by the manufacturer of the complete product.
7. Do not check high voltage by drawing an arc. Use a high voltage meter or a high voltage probe with a VTVM. Discharge the picture tube before attempting meter connection, by connecting a clip lead to the ground frame and connecting the other end of the lead through a 10kΩ 2W resistor to the anode button.
8. When service is required, observe the original lead dress. Extra precaution should be given to assure correct lead dress in the high voltage circuit area. Where a short circuit has occurred, those components that indicate evidence of overheating should be replaced. Always use the manufacturer's replacement components.

9. Isolation Check

(Safety for Electrical Shock Hazard)

After re-assembling the product, always perform an isolation check on the exposed metal parts of the cabinet (antenna terminals, video/audio input and output terminals, Control knobs, metal cabinet, screw heads, earphone jack, control shafts, etc.) to be sure the product is safe to operate without danger of electrical shock.

(1) Dielectric Strength Test

The isolation between the AC primary circuit and all metal parts exposed to the user, particularly any exposed metal part having a return path to the chassis should withstand a voltage of 3000V AC (r.m.s.) for a period of one second.

(... Withstand a voltage of 1100V AC (r.m.s.) to an appliance rated up to 120V, and 3000V AC (r.m.s.) to an appliance rated 200V or more, for a period of one second.)

This method of test requires a test equipment not generally found in the service trade.

(2) Leakage Current Check


Plug the AC line cord directly into the AC outlet (do not use a line isolation transformer during this check.). Using a "Leakage Current Tester", measure the leakage current from each exposed metal part of the cabinet, particularly any exposed metal part having a return path to the chassis, to a known good earth ground (water pipe, etc.). Any leakage current must not exceed 0.5mA AC (r.m.s.).

However, in tropical area, this must not exceed 0.2mA AC (r.m.s.).

● Alternate Check Method

Plug the AC line cord directly into the AC outlet (do not use a line isolation transformer during this check.). Use an AC voltmeter having 1000 ohms per volt or more sensitivity in the following manner. Connect a 1500Ω 10W resistor paralleled by a 0.15μF AC-type capacitor between an exposed metal part and a known good earth ground (water pipe, etc.). Measure the AC voltage across the resistor with the AC voltmeter. Move the resistor connection to each exposed metal part, particularly any exposed metal part having a return path to the chassis, and measure the AC voltage across the resistor. Now, reverse the plug in the AC outlet and repeat each measurement. Any voltage measured must not exceed 0.75V AC (r.m.s.). This corresponds to 0.5mA AC (r.m.s.).

However, in tropical area, this must not exceed 0.3V AC (r.m.s.). This corresponds to 0.2mA AC (r.m.s.).






FEATURES




- The TELETEXT SYSTEM has a built-in FASTEXT/WST System. [AV-34LS, AV-34LS-AU, AV-3408TEE]
- New chassis design enables use of an interactive on-screen control.
- Pure flat CRT produces fine textured picture in every detail.
- Wide range voltage (110V ~ 240V) for AC power input.
- With AUDIO/VIDEO/S-VIDEO/COMPONENT input terminals. (S-VIDEO : AV-34LS-AU)
- I² C bus control utilizes single chip ICs.
- By means of AUTO PROGRAM, the TV stations can be selected automatically and the TV channels can also be rearranged automatically.
- Built-in DIGITAL ECO MODE (ECONOMY, ECOLOGY).
In accordance with the brightness in a room, the brightness and/or contrast of the picture can be adjusted automatically to make the optimum picture which is easy on the eye.
- Built-in ON TIMER & RETURN +.

MAIN DIFFERENCE LIST

[AV-34LS & AV-34LS-AU & AV-34LH]


△	Part Name	MODEL No.	AV-34LS	AV-34LS-AU	AV-34LH
△	POWER CORD		QMP40D0-200J5 or QMP40D0-200J3 	QMP2980-185J5 	QMPN050-200-E2 
△	RATING LABEL		LC20377-001B-H	LC20377-013B-H	LC20377-012B-H
	FRONT CABI ASS'Y		LC11231-002B-H	←	LC11231-003A-H
△	REAR COVER		LC10180-004A-HH	LC10180-006A-H	←
	AV TERMINAL BOARD		LC11064-002A-H	LC11064-001B-H	LC11064-002A-H
	MAIN PWB ASS'Y		SCH-1007A-H2	SCH-1037A-H2	SCH-1036A-H2
	REMOTE CONTROL UNIT		RM-C352-1C	←	RM-C353-1C
△	INST BOOK		LCT0935-001B-H	←	LCT1006-001B-H
	WARRANTY CARD		—	BT-56001-2	—
	SERVICE CENTER LIST		—	BT-56002-2	—

[AV-34LX & AV-34LX-A & AV-3408TEE]

△	Part Name	MODEL No.	AV-34LX	AV-34LX-A	AV-3408TEE
△	POWER CORD		QMP40D0-200J5 or QMP40D0-200J3 	QMPR010-200-E2 or QMPR010-200-K2 	QMP40D0-200J5 or QMP40D0-200J3 
△	RATING LABEL		LC20377-010B-H	LC20413-002B-H	LC20377-009B-H
	FRONT CABI ASS'Y		LC11231-004B-H	←	LC11231-007A-H
△	REAR COVER		LC10180-004A-HH	←	←
	MAIN PWB ASS'Y		SCH-1008A-H2	←	SCH-1038A-H2
	REMOTE CONTROL UNIT		RM-C357-1C	←	RM-C355-1C
△	INST BOOK		LCT0935-001B-H	←	LCT1007-001A-H
	WARRANTY CARD		—	—	BT-54012-2
△	CONVERSION PLUG		—	QAM0055-001	—


FUNCTIONS

■ FRONT PANEL




■ REAR PANEL

[AV-34LS, AV-34LH, AV-34LX, AV-34LX-A, AV-3408TEE]




[AV-34LS-AU]




■ REMOTE CONTROL UNIT


RM-C352-1C
[AV-34LS, AV-34LS-AU]




RM-C353-1C
[AV-34LH]



RM-C355-1C
[AV-3408TEE]



RM-C357-1C
[AV-34LX, AV-34LX-A]



SPECIFIC SERVICE INSTRUCTIONS

DISASSEMBLY PROCEDURE

REMOVING THE REAR COVER

1. Unplug the AC power cord.
2. Remove the 18 screws marked (A) as shown in Fig.1.
3. Withdraw the Rear cover toward you.

[CAUTION]

- When reinstalling the rear cover, carefully push it inward after inserting the Main PWB into the rear cover groove.

REMOVING THE CHASSIS (CHASSIS BASE AND CONTROL BASE)

- After removing the rear cover.
1. Slightly raise the both sides of the chassis by hand and remove the 2 claws marked (B) under the chassis from the front cabinet as shown in Fig.1.
 2. Withdraw the chassis backward.

(If necessary, take off the wire clamp, connector's etc.)

* When conducting a check with power supplied, be sure to confirm that the CRT earth wire is connected to the CRT Socket PWB and the Main PWB.

CHECKING THE MAIN PW BOARD

1. To check the back side of the Main PWB.
 - 1) Pull out the chassis. (Refer to REMOVING THE CHASSIS).
 - 2) Erect the chassis vertically so that you can easily check the back side of the Main PWB.

[CAUTION]

- When erecting the chassis, be careful so that there will be no contacting with other PW Board.
- Before turning on power, make sure that the CRT earth wire and other connectors are properly connected.
- When repairing, connect the Deg. coil to the DEG. connector on the Main PWB.

WIRE CLAMPING AND CABLE TYING

1. Be sure to clamp the wire.
2. Never remove the cable tie used for tying the wires together. Should it be inadvertently removed, be sure to tie the wires with a new cable tie.

REMOVING THE AV TERMINAL BOARD

- After removing the rear cover.
1. Remove the 4 screws marked (C) as shown in Fig.1.
 2. When you pull out the AV Terminal board in the direction of arrow marked (D) as shown in Fig.1, it can be removed.

REMOVING THE CONTROL BASE

- After removing the rear cover and the chassis.
1. While pushing down the 2 claws maked (E) as shown in Fig. 2.
 2. When you pull out the Control base in the direction of arrow maked (F) as shown in Fig. 2.

(If necessary, take off the wire, connector's etc.)

REMOVING THE SPEAKER

- After removing the rear cover.
1. Remove the 4 screws marked (G) as shown in Fig.1.
 2. Withdraw the speaker backward.
 3. Follow the same steps when removing the other hand speaker.




Fig.1

REMOVING THE CRT

* Replacement of the CRT should be performed by 2 or more persons.

- After removing the rear cover, chassis etc.,
 - 1. Putting the CRT change table on soft cloth, the CRT change table should also be covered with such soft cloth (shown in Fig. 3).
 - 2. While keeping the surface of CRT down, mount the TV set on the CRT change table balanced will as shown in Fig. 4.
 - 3. Remove 4 screws marked by arrows with a box type screwdriver as shown in Fig. 4.
 - Since the cabinet will drop when screws have been removed, be sure to support the cabinet with hands.
 - 4. After 4 screws have been removed, put the cabinet slowly on cloth (At this time, be carefully so as not to damage the front surface of the cabinet) shown in Fig. 5.
 - The CRT should be assembled according to the opposite sequence of its dismantling steps.
- * The CRT change table should preferably be smaller than the CRT surface, and its height be about 35cm.




Fig. 3




Fig. 4

COATING OF SILICON GREASE FOR ELECTRICAL INSULATION ON THE CRT ANODE CAP SECTION.

- Subsequent to replacement of the CRT and HV transformer or repair of the anode cap, etc. by dismantling them, be sure to coat silicon grease for electrical insulation as shown in Fig. 6.
- 1. Wipe around the anode button with clean and dry cloth. (Fig. 6)
- 2. Coat silicon grease on the section around the anode button. At this time, take care so that any silicon greases dose not sticks to the anode button. (Fig. 7)

★ Silicon grease product No. KS - 650N




Fig. 5




Fig. 6




Fig. 7

REPLACEMENT OF MEMORY IC

1. MEMORY IC

This TV uses the following memory IC.

Memory IC: IC1702 on MAIN PW Board

The memory IC memorizes data for correctly operating the video and deflection circuits. When replacing the memory IC, be sure to use the same type IC written with the initial values of data. In other words, use the specific IC listed in "PRINTED WIRING BOARD PARTS LIST". For its mounting location, refer to "ADJUSTMENT LOCATIONS".

2. PROCEDURE FOR REPLACING MEMORY IC

(1) Power off

Switch the power off and unplug the power cord from the wall outlet.

(2) Replacing the memory IC

Replace the memory IC with new one. Be sure to use the memory IC written with the initial data values.

(3) Power on


Plug the power cord into the wall outlet and switch the power on.

(4) Check and setting of SYSTEM CONSTANT SET:

- 1) Press the DISPLAY key and the PICTURE MODE key on the remote control unit simultaneously.
The SERVICE MENU screen will be displayed.(See Fig.1.)
- 2) In the SERVICE MENU, press the DISPLAY key and PICTURE MODE key simultaneously. Then, the SYSTEM CONSTANT SET screen will be displayed.(See Fig.2.)
- 3) Check whether the setting values of the SYSTEM CONSTANT SET are the same as those indicated in Table 1.
If the value is different, select the setting item with the MENU ∇/Δ key, and set the correct value with the MENU $-/+$ key.
- 4) Press the DISPLAY key twice to return to the normal screen.

(5) Receive channel setting

Refer to the **OPERATING INSTRUCTIONS** and set the receive channels (channels preset).



(6) User setting

Check the user setting values in Table 2, and if setting value is different, set the correct value.

For setting, refer to the **OPERATING INSTRUCTIONS**.

(7) Setting of SERVICE MENU

Verify the setting for each setting item in the SERVICE MENU.(See Table 3.) If readjustment is necessary, perform adjustment referring to "SERVICE ADJUSTMENTS".




Fig. 1




Fig. 2

SETTING OF SYSTEM CONSTANT SET

Setting item	Setting content	Setting value					
		AV-34LS	AV-34LS-AU	AV-34LH	AV-34LX	AV-34X-A	AV-3408TEE
SYSTEM		MULTI	←	←	←	←	←
COMB		YES	←	←	←	←	←
TILT		YES	←	←	←	←	←
TEXT		ARABIC	PAN EURO	NO	←	←	RUSSIAN
SUPPER BASS		NO	←	←	←	←	←
LANGUAGE		E/R/C	←	E/C	E/R/A/F	←	E/R
MSP		YES	←	←	NO	←	←
BILINGUAL		NO	←	←	←	←	←
B/B SOUND		NO	←	←	←	YES	←
TUNER		MU	←	←	←	←	←
COLOUR AUTO		NO	←	←	←	YES	←
LOCK 1MHz		020	←	←	←	←	←
500KHz		020	←	←	←	←	←
250KHz		020	←	←	←	←	←
156.25KHz		015	←	←	←	←	←
		015	←	←	←	←	←

Table 1

USER SETTING VALUES

Setting item	Setting value
SUB POWER	ON
CHANNEL POSITION	1 POSITION
CHANNEL PRESET	REFER TO OPERATING INSTRUCTIONS
VOLUME	15 ± 2
TV/VIDEO	TV
VNR	OFF
COMPRESS (16:9)	OFF
AUTO SHUTOFF	OFF
CHILD LOCK	OFF
BLUE BACK	ON
VIDEO-2 SET	VIDEO
LANGUAGE	ENG
MONO SURROUND	OFF [AV-34LX/LX-A, AV-3408TEE]
AI VOLUME	ON
ON SCREEN DISPLAY	POSITION INDICATION
COLOUR SYSTEM	PAL
SOUND SYSTEM	B/G
STEREO MODE	STEREO [AV-34LS/LS-AU/LH]
PICTURE MODE-VSM	BRIGHT
OFF TIMER	00
ECO SENSOR	OFF
PICTURE TILT	00
BASS	CENTRE
TREBLE	CENTRE
BALANCE	CENTRE

Table 2

SERVICE MENU SETTING ITEMS

Service menu	Setting item	Service menu	Setting item
1. IF	1. VCO 2. DELAY POINT	5. PRESET Do not adjust	1. CB 2. ACL 3. MUS 4. MAT 5. FCO 6. BPS 7. IFLH 8. VID 9. STM 10. AFCW 11. VSW 12. FFI 13. AGC 14. CL 15. AKB 16. HBL 17. BKS 18. READ STATUS 19. VNR
2. VC	1. CUTOFF(R/G) 2. DRIVE(R/G/B) 3. BRIGHT 4. CONT 5. COLOUR 6. TINT 7. SHARP 8. YDELAY] Do not adjust		
3. DEF	1. VER. SLOPE 2. VER. HEIGHT 3. VER. POSITION 4. VER. SCURVE 5. HOR. POSITION 6. HOR. WIDTH 7. EW-PIN 8. EW-TRAPEZ 9. UP CORNER 10. DW CORNER 11. HOR. PARALL 12. HOR. BOW 13. V. ZOOM		
4. VSM PRESET (BRIGHT/STD/SOFT) Do not adjust	1. TINT 2. COLOUR 3. BRIGHT 4. CONT 5. SHARP	6. AUDIO [Only AV-34LS/LS-AU/LH] Do not adjust	1. ERROR LIMIT 2. A2 ID THR 3. SOUND SYSTEM
		6 / 7. PLUG & PLAY(OFF) Do not adjust	

Table 3

REPLACEMENT OF CHIP COMPONENT

■ CAUTIONS

1. Avoid heating for more than 3 seconds.
2. Do not rub the electrodes and the resist parts of the pattern.
3. When removing a chip part, melt the solder adequately.
4. Do not reuse a chip part after removing it.

■ SOLDERING IRON


1. Use a high insulation soldering iron with a thin pointed end of it.
2. A 30w soldering iron is recommended for easily removing parts.

■ REPLACEMENT STEPS


1. How to remove Chip parts

◆ Resistors, capacitors, etc.

- (1) As shown in the figure, push the part with tweezers and alternately melt the solder at each end.




- (2) Shift with tweezers and remove the chip part.




◆ Transistors, diodes, variable resistors, etc.

- (1) Apply extra solder to each lead.



- (2) As shown in the figure, push the part with tweezers and alternately melt the solder at each lead. Shift and remove the chip part.




Note : After removing the part, remove remaining solder from the pattern.


2. How to install Chip parts

◆ Resistors, capacitors, etc.

- (1) Apply solder to the pattern as indicated in the figure.




- (2) Grasp the chip part with tweezers and place it on the solder. Then heat and melt the solder at both ends of the chip part.




◆ Transistors, diodes, variable resistors, etc.

- (1) Apply solder to the pattern as indicated in the figure.
- (2) Grasp the chip part with tweezers and place it on the solder.
- (3) First solder lead **A** as indicated in the figure.



- (4) Then solder leads **B** and **C**.



SERVICE ADJUSTMENTS

ADJUSTMENT PREPARATION:

1. You can make the necessary adjustments for this unit with either the remote control unit or with the adjustment equipment and parts as given below.
2. Adjustment with the remote control unit is made on the basis of the initial setting values, however, the new setting values which set the screen to its optimum condition may differ from the initial settings.
3. Make sure that AC power is turned on correctly.
4. Turn on the power for the set and test equipment before use, and start the adjustment procedures after waiting at least 30 minutes.
5. Unless otherwise specified, prepare the most suitable reception or input signal for adjustment.
6. Never touch any adjustment parts, which are not specified in the list for this adjustment-variable resistors, transformers, capacitors, etc.
7. Presetting before adjustment.

Unless otherwise specified in the adjustment instructions, preset the following functions with the remote control unit.

- User mode setting position

Setting item	Setting value
PICTURE MODE(VSM)	BRIGHT
VNR	OFF
BASS,TREBLE,BALANCE	CENTRE
TINT,COLOUR,BRIGHT,CONT,SHARP	CENTRE

MEASURING INSTRUMENT


1. DC voltmeter (or Digital voltmeter)
2. Oscilloscope
3. Signal generator (Pattern generator) [PAL/SECAM/NTSC]
4. Remote control unit

ADJUSTMENT ITEMS


- B1 POWER SUPPLY
- FOCUS adjustment
- IF circuit adjustment
 - VCO (CW) adjustment
 - DELAY POINT adjustment
- VC (VIDEO/CHROMA) circuit adjustment
 - WHITE BALANCE (Low light) adjustment
 - WHITE BALANCE (High light) adjustment
 - SUB BRIGHT adjustment
 - SUB CONT adjustment
 - SUB COLOUR adjustment
 - SUB TINT adjustment
- DEFLECTION circuit adjustment
 - VER. SLOPE adjustment
 - VER. POSITION adjustment
 - V. ZOOM adjustment
 - HOR. POSITION adjustment
 - HOR. WIDTH adjustment
 - EW-PIN adjustment
 - EW-TRAPEZ adjustment
 - VER. SCURVE adjustment
 - UP CORNER and DW CORNER adjustment
 - HOR. PARALL adjustment
 - HOR. BOW adjustment
- VSM PRESET adjustment
- PRESET adjustment
- AUDIO adjustment
- PURITY and CONVERGENCE adjustments
 - PURITY adjustment
 - STATIC CONVERGENCE adjustment
 - DYNAMIC CONVERGENCE adjustment

ADJUSTMENT LOCATIONS


FRONT CONTROL PWB(1/2)



FRONT CONTROL PWB(2/2)




MAIN PWB



CRT SOCKET PWB

(SOLDER SIDE)



BASIC OPERATION IN SERVICE MENU

1. TOOL OF SERVICE MENU OPERATION

Operate the SERVICE MENU with the remote control unit.

2. SERVICE MENU ITEMS

With the SERVICE MENU, various settings (adjustments) can be made, and they are broadly classified in the following items of settings:

- 1. IF For entering/adjusting the setting values (adjustment values) of the IF circuit.
- 2. VC For entering/adjusting the setting values (adjustment values) of the VIDEO/CHROMA circuit.
- 3. DEF For entering/adjusting the setting values (adjustment values) of the DEFLECTION circuit.
- 4. VSM PRESET For setting the values of STANDARD, SOFT and BRIGHT.
(VSM: video status memory)
- 5. PRESET For setting the values of the preset.
- 6. AUDIO For entering/adjusting the setting values (adjustment values) of the multiplicity sound circuit.
[Only AV-34LS/LS-AU/LH]
- 6/7. PLUG & PLAY (OFF) .. This is not used for service.

3. BASIC OPERATION IN SERVICE MENU

(1) How to enter SERVICE MENU

Press the DISPLAY key and the PICTURE MODE key on the remote control unit simultaneously.

The SERVICE MENU screen will be displayed. (See Fig. 1 on the next page.)

(2) Selection of SUB MENU SCREEN

Press one of the keys 1 to 7 on the remote control unit, and select the SUB MENU SCREEN from the SERVICE MENU. (See Fig. 1 on the next page.)

SERVICE MENU → SUB MENU	1. IF
	2. VC
	3. DEF
	4. VSM PRESET
	5. PRESET
	6. AUDIO [Only AV-34LS/LS-AU/LH]
	6/7. PLUG & PLAY (OFF)

(3) Method of Setting

*Once the setting values are set, they are memorized automatically.

*It must not adjust without inputting a signal.

1) 1. IF

[1. VCO]

- (a) 1 Key Select **1. IF**.
- (b) 1 Key Select **1. VCO**.
- (c) DISPLAY Key When this is pressed twice, you will return to the SERVICE MENU.
● Under normal conditions, no adjustment is required.

[2. DELAY POINT]

- (a) 1 Key Select **1. IF**.
- (b) 2 Key Select **2. DELAY POINT**.
- (c) MENU ∇/Δ Key Adjust the setting value.
- (d) DISPLAY Key When this is pressed twice, you will return to the SERVICE MENU.

2) 2. VC, 3. DEF, 4. VSM PRESET, 5. PRESET and 6. AUDIO

- (a) 2 ~ 6 Keys Select one from **2. VC**, **3. DEF**, **4. VSM PRESET**, **5. PRESET** and **6. AUDIO**.
- (b) MENU ∇/Δ key Select setting items.
- (c) MENU \rightarrow Key Adjust the setting values of the setting items.
● Use the number keys on the remote control unit for setting of WHITE BALANCE.
For the setting, refer to each item concerned.
- (d) DISPLAY Key When this is pressed, you will return to the SERVICE MENU.

3) 6/7. PLUG & PLAY (OFF)

This is not used for service.

(4) Release of SERVICE MENU

After completing the setting, return to the SERVICE MENU by pressing the DISPLAY key, then again press the DISPLAY key to return to the normal screen.




Fig. 1

ADJUSTMENTS

B1 POWER SUPPLY


Item	Measuring instrument	Test point	Adjustment part	Description
Check of B1 POWER SUPPLY	Signal Generator DC Voltmeter	B1 (pin 1) GND (pin 5) [CN00S connector]		<ol style="list-style-type: none"> 1. Receive a black and white signal. 2. Connect a DC voltmeter between B1 and GND (between pins 1 and 5 of the connector CN00S). 3. Make sure that the voltage is DC134.5 ± 2V.

FOCUS ADJUSTMENT

Item	Measuring instrument	Test point	Adjustment part	Description
Adjustment of FOCUS	Signal generator		FOCUS VR1,2 [In HVT]	<p>Notes:</p> <ul style="list-style-type: none"> • Proceed to the following this adjustment after having completed the adjustments of B1 POWER SUPPLY, SUB BRIGHT and SUB CONT. • Set PICTURE MODE (VSM) to "BRIGHT". • The final adjustment of CONVERGENCE must be done after the FOCUS adjustment. (CONVERGENCE is changed by FOCUS adjustment.) <p>When makes difference by FOCUS adjustment, should be reconfirming PURITY adjustment.</p> <ol style="list-style-type: none"> 1. Receive a cross-hatch signal. 2. While looking at the screen centre, adjust the FOCUS VR2 (F2) so that the horizontal lines will be clear and in fine detail. 3. Adjust the FOCUS VR1 (F1) so that the vertical lines will be clear and in fine detail. 4. Make sure that the picture is in focus even when the screen gets darkened.

IF CIRCUIT ADJUSTMENT

Item	Measuring instrument	Test point	Adjustment part	Description
Adjustment of VCO (CW)	Remote control unit		VCO (CW)	<p>Note:</p> <ul style="list-style-type: none"> • Under normal conditions, no adjustment is required. <ol style="list-style-type: none"> 1. Select 1. IF from the SERVICE MENU. 2. Select 1. VCO by pressing the 1 key on the remote control unit. 3. Receive a broadcast signal. 4. Check the characters colour of the BELOW REFERENCE displayed to yellow. 5. Press the DISPLAY key three times to return to normal screen.
Adjustment of DELAY POINT	Remote control unit		DELAY POINT (AGC TAKE-OVER)	<ol style="list-style-type: none"> 1. Receive a black and white broadcast signal (colour off). 2. Select 1. IF from the SERVICE MENU. 3. Select 2. DELAY POINT by pressing the 2 key on the remote control unit. 4. Adjust the MENU -/+ key in order to eliminate any noise or beat from the image. Any increase above the initial value produces noise and any decrease below it produces beat. 5. Press the DISPLAY key three times to return to the normal screen. 6. Turn to other channels and make sure that there are no irregularities.



Setting (Adjustment time)		Initial setting value
DELAY POINT (AGC TAKE-OVER)	NTSC 3.58	17
	OTHERS	15

VC (VIDEO/CHROMA) CIRCUIT ADJUSTMENT

The setting (adjustment) using the remote control unit is made on the basis of the initial setting values.
The setting values which adjust the screen to the optimum condition can be different from the initial setting values.
● Do not change the initial setting values of the setting (adjustment) items not listed in "ADJUSTMENT".


[SUB MENU 2. VC] : Do not adjust.

	Setting (Adjustment) item	Variable range	Initial setting value				
			PAL	SECAM	NTSC3.58	NTSC4.43	COMPONENT
1	CUTOFF(R/G)	-7 — +8	0	←	←	←	←
2	DRIVE(R/G/B)	-32 — +31	0	←	←	←	←
3	BRIGHT(COM./TV/V-1/V-2/V-3)	-32 — +31	-1/-16/0/0/0	←	←	←	←
4	CONT	-32 — +31	0	←	←	←	—
5	COLOUR	-32 — +31	-5	-3	-12	+1	+10
6	TINT (TV/VIDEO)	-32 — +31	—	—	-15/+6	+1/+1	—
7	SHARP (TV/VIDEO)	-32 — +31	-24/-10	←	←	←	—/0
8	YDELAY (TV/VIDEO/S)	-8 — +7	0/+1/0	+5/+1/+1	0/+1/+1	+5/0/+1	—


Item	Measuring instrument	Test point	Adjustment part	Description											
Adjustment of WHITE BALANCE (Low light)	Signal generator		1. CUTOFF (R) CUTOFF (G)	Note: •Set PICTURE MODE (VSM) to “BRIGHT”.											
	Remote control unit		SCREEN VR [In HVT]												
	<div><div>V/C PAL</div><div>1. CUTOFF (R) **</div><div> (G) **</div><div>50 Hz</div><div>MENU ▲▼: SELECT</div><div>MENU -/+ : OPERATE DISPLAY : EXIT</div></div>														
	<div><div>REMOTE CONTROL UNIT</div><div><div>H.LINE OFF</div><div>H.LINE ON</div><div>R. CUTOFF (▲)</div><div>R. CUTOFF (▼)</div></div><div><div>1</div><div>2</div><div>4</div><div>5</div><div>7</div><div>8</div><div>3</div><div>6</div><div>9</div></div><div><div>G. CUTOFF (▲)</div><div>G.CUTOFF (▼)</div></div></div>														
				<table><tr><th>Setting (Adjustment) Item</th><th></th><th>Variable range</th><th>Initial setting value</th></tr><tr><td rowspan="2">1. CUT OFF</td><td>R</td><td>-7 — +8</td><td>0</td></tr><tr><td>G</td><td>-7 — +8</td><td>0</td></tr></table>	Setting (Adjustment) Item		Variable range	Initial setting value	1. CUT OFF	R	-7 — +8	0	G	-7 — +8	0
Setting (Adjustment) Item		Variable range	Initial setting value												
1. CUT OFF	R	-7 — +8	0												
	G	-7 — +8	0												

Item	Measuring instrument	Test point	Adjustment part	Description													
Adjustment of WHITE BALANCE (High light)	Signal generator		2. DRIVE (R) DRIVE (G) DRIVE (B)	<p>Notes:</p> <ul style="list-style-type: none">• Proceed to the following this adjustment after having completed the adjustment of LOW LIGHT WHITE BALANCE.• Set PICTURE MODE (VSM) to “BRIGHT”. <ol style="list-style-type: none">1. Receive a PAL black and white signal (colour off).2. Select 2. VC from the SERVICE MENU.3. Select 2. DRIVE (R), (G) and (B) with MENU ▽/△ key, and set each value to initial setting value with the 4 to 9 keys on the remote control unit.4. Use the keys 4 to 9 to produce a white screen.5. Press the DISPLAY key twice to return to the normal screen. <table><tr><th>Setting (Adjustment) Item</th><th>Variable range</th><th>Initial setting value</th></tr><tr><td rowspan="3">2. DRIVE</td><td>R</td><td>−32 — +31</td><td>0</td></tr><tr><td>G</td><td>−32 — +31</td><td>0</td></tr><tr><td>B</td><td>−32 — +31</td><td>0</td></tr></table>	Setting (Adjustment) Item	Variable range	Initial setting value	2. DRIVE	R	−32 — +31	0	G	−32 — +31	0	B	−32 — +31	0
	Setting (Adjustment) Item	Variable range			Initial setting value												
2. DRIVE	R	−32 — +31	0														
	G	−32 — +31	0														
	B	−32 — +31	0														
	Remote control unit	<div><div>V/C</div><div>PAL</div><div>1. DRIVE (R) **</div><div>(G) **</div><div>(B) **</div><div>50 Hz</div><div>MENU ▲▼ : SELECT</div><div>MENU −/+ : OPERATE DISPLAY : EXIT</div></div>															
				<div><div>REMOTE CONTROL UNIT</div><div><div>1</div><div>2</div><div>3</div><div>4</div><div>5</div><div>6</div><div>7</div><div>8</div><div>9</div><div>R. DRIVE (▲)</div><div>G. DRIVE (▲)</div><div>R. DRIVE (▼)</div><div>B. DRIVE (▲)</div><div>G. DRIVE (▼)</div><div>B. DRIVE (▼)</div></div></div>													
Adjustment of SUB BRIGHT	Remote control unit		3. BRIGHT	<p>Notes:</p> <ul style="list-style-type: none">• Proceed to the following this adjustment after having completed the adjustments of LOW LIGHT WHITE BALANCE and HIGH LIGHT WHITE BALANCE.• Set PICTURE MODE (VSM) to “BRIGHT”. <ol style="list-style-type: none">1. Receive a broadcast.2. Select 2. VC from the SERVICE MENU.3. Select 3. BRIGHT with the MENU ▽/△ key.4. Set the initial setting value with the MENU −/+ key.5. If the brightness is not best with the initial setting value, make fine adjustment until you get the best brightness.6. Press the DISPLAY key twice to return to the normal screen.													
Adjustment of SUB CONT	Remote control unit		4. CONT	<p>Notes:</p> <ul style="list-style-type: none">• Proceed to the following this adjustment after having completed the adjustment of SUB BRIGHT.• Set PICTURE MODE (VSM) to “BRIGHT”. <ol style="list-style-type: none">1. Receive a broadcast.2. Select 2. VC from the SERVICE MENU.3. Select 4. CONT with the MENU ▽/△ key.4. Set the initial setting value with the MENU −/+ key.5. If the contrast is not best with the initial setting value, make fine adjustment until you get the best contrast.6. Press the DISPLAY key twice to return to the normal screen.													

Item	Measuring instrument	Test point	Adjustment part	Description
Adjustment of SUB COLOUR-I	Remote control unit		5. COLOUR	<p>[Method of adjustment without measuring instrument]</p> <p>Notes:</p> <ul style="list-style-type: none"> • Proceed to the following this adjustment after having completed the adjustment of SUB CONT. • Set PICTURE MODE (VSM) to "BRIGHT". <p>– PAL COLOUR –</p> <ol style="list-style-type: none"> 1. Receive a PAL broadcast. 2. Select 2. VC from the SERVICE MENU. 3. Select 5. COLOUR with the MENU ∇/Δ key. 4. Set the initial setting value for PAL COLOUR with the MENU $\rightarrow/+$ key. 5. If the colour is not best with the initial setting value, make fine adjustment until you get the best colour. 6. Press the DISPLAY key twice to return to the normal screen. <p>– SECAM COLOUR –</p> <ol style="list-style-type: none"> 7. Receive a SECAM broadcast. 8. Press the COLOUR SYSTEM button on the remote control unit to select the SECAM colour system. 9. Make fine adjustment of SECAM COLOUR in the same way as for "PAL COLOUR". <p>– NTSC 3.58 COLOUR –</p> <ol style="list-style-type: none"> 10. Receive a NTSC 3.58MHz broadcast. 11. Press the COLOUR SYSTEM button on the remote control unit to select the NTSC 3.58 colour system. 12. Make similar fine adjustment of NTSC 3.58 COLOUR in the same way as for "PAL COLOUR". <p>– NTSC 4.43 COLOUR –</p> <p>When adjustment is done for NTSC 3.58 COLOUR, appropriate values are automatically set for NTSC 4.43 COLOUR.</p>
Adjustment of SUB COLOUR-II	Signal generator Oscilloscope Remote control unit	TP-47G TP-E (77) [CRT SOCKET PWB]	5. COLOUR	<p>[Method of adjustment using measuring instrument]</p> <p>Notes:</p> <ul style="list-style-type: none"> • Proceed to the following this adjustment after having completed the adjustment of SUB CONT. • Set PICTURE MODE (VSM) to "BRIGHT". <p>– PAL COLOUR –</p> <ol style="list-style-type: none"> 1. Receive a PAL colour bar signal (full field colour bar 75% white). 2. Select 2. VC from the SERVICE MENU. 3. Select 5. COLOUR with the MENU ∇/Δ key. 4. Set the initial setting value of PAL COLOUR with the MENU $\rightarrow/+$ key. 5. Connect the oscilloscope between TP-47G and TP-E. 6. Adjust PAL COLOUR to set the value (A) in the figure to +8V (V_{W-G}). <p>– SECAM COLOUR –</p> <ol style="list-style-type: none"> 7. Receive a SECAM colour bar signal (full field colour bar 75% white). 8. Press the COLOUR SYSTEM button on the remote control unit to select the SECAM colour system. 9. Set the initial setting value of SECAM COLOUR with the MENU $\rightarrow/+$ key. 10. Adjust SECAM COLOUR to set the value (A) in the figure to +2V (V_{W-G}). <p>– NTSC 3.58 COLOUR –</p> <ol style="list-style-type: none"> 11. Receive a NTSC 3.58 colour bar signal (full field colour bar 75% white). 12. Press the COLOUR SYSTEM button on the remote control unit to select the NTSC 3.58 colour system. 13. Set the initial setting value of NTSC 3.58 COLOUR with the MENU $\rightarrow/+$ key. 14. Adjust NTSC 3.58 COLOUR to set the value (A) in the figure to +2V (V_{W-G}). <p>– NTSC 4.43 COLOUR –</p> <p>When adjustment is done for NTSC 3.58 COLOUR, appropriate values are automatically set for NTSC 4.43 COLOUR.</p>



Item	Measuring instrument	Test point	Adjustment part	Description
Adjustment of SUB TINT-I	Remote control unit		6. TINT	<p>[Method of adjustment without measuring instrument]</p> <p>Notes:</p> <ul style="list-style-type: none"> • Proceed to the following this adjustment after having completed the adjustment of SUB CONT. • Set PICTURE MODE (VSM) to "BRIGHT". <p>– NTSC 3.58 TINT –</p> <ol style="list-style-type: none"> 1. Receive a NTSC 3.58 colour bar signal (full field colour bar 75% white). 2. Press the COLOUR SYSTEM button on the remote control unit to select the NTSC 3.58 colour system. 3. Select 2. VC from the SERVICE MENU. 4. Select 6. TINT with the MENU ∇/Δ key. 5. Set the initial setting value of NTSC 3.58 with the MENU $-/+$ key. 6. If you cannot get the best tint with the initial setting value, make fine adjustment until you get the best tint. 7. Press the DISPLAY key twice to return to the normal screen. <p>– NTSC 4.43 TINT –</p> <p>When adjustment is done for NTSC 3.58 TINT, appropriate values are automatically set for NTSC 4.43 TINT.</p>
Adjustment of SUB TINT-II	Signal generator Oscilloscope Remote control unit	TP-47G TP-E (77) [CRT SOCKET PWB]	6. TINT	<p>[Method of adjustment using measuring instrument]</p> <p>Notes:</p> <ul style="list-style-type: none"> • Proceed to the following this adjustment after having completed the adjustment of SUB CONT. • Set PICTURE MODE (VSM) to "BRIGHT". <p>– NTSC 3.58 TINT –</p> <ol style="list-style-type: none"> 1. Receive a NTSC 3.58 colour bar signal (full field colour bar 75% white). 2. Press the COLOUR SYSTEM button on the remote control unit to select the NTSC 3.58 colour system. 3. Select 2. VC from the SERVICE MENU. 4. Select 6. TINT with the MENU ∇/Δ key. 5. Set the initial setting value of NTSC 3.58 with the MENU $-/+$ key. 6. Connect the oscilloscope between TP-47G and TP-E. 7. Adjust NTSC 3.58 TINT to set the value (B) in the figure to 0V (V_{w-cy}). 8. Press the DISPLAY key twice to return to the normal screen. <p>– NTSC 4.43 TINT –</p> <p>When adjustment is done for NTSC 3.58 TINT, appropriate values are automatically set for NTSC 4.43 TINT.</p>



DEFLECTION CIRCUIT ADJUSTMENT

The setting (adjustment) using the remote control unit is made on the basis of the initial setting values.
The setting values which adjust the screen to the optimum condition can be different from the initial setting values.



Note:




Proceed to the following this adjustment after having completed the adjustments of SUB BRIGHT and SUB CONT.




[SUB MENU 3. DEF]

Setting (Adjustment) item	Variable range	Initial setting value				
		4:3		COMPRESS(16:9)		COMPONENT DVD(50Hz/60Hz)
		50Hz	60Hz	50Hz	60Hz	
1. VER. SLOPE	-32 — +31	+3	0	—	—	—
2. VER. HEIGHT	-32 — +31	+31	+31	-23	-24	—
3. VER. POSITION	-32 — +31	+2	-1	—	—	—
4. VER. SCURVE	-32 — +31	-21	0	—	—	—
5. HOR. POSITION	-32 — +31	+8	+7	—	—	+7
6. HOR. WIDTH	-32 — +31	+11	-1	—	—	—
7. EW-PIN	-32 — +31	-11	-1	-13	-12	—
8. EW-TRAPEZ	-32 — +31	0	0	—	—	—
9. UP CORNER	-32 — +31	-25	0	0	0	—
10. DW CORNER	-32 — +31	-25	0	0	0	—
11. HOR. PARALL	-32 — +31	0	0	—	—	—
12. HOR. BOW	-32 — +31	0	0	—	—	—
13. V.ZOOM	-32 — +31	+7	-1	+6	+6	—


[fv : 50Hz mode]

Item	Measuring instrument	Test point	Adjustment part	Description
Adjustment of VER. SLOPE	Signal generator Remote control unit		1. VER. SLOPE	<ol style="list-style-type: none"> 1. Receive a PAL circle pattern signal of vertical frequency 50Hz. 2. Select 3. DEF from the SERVICE MENU. 3. Select 1. VER. SLOPE with the MENU ∇/Δ key. 4. Set the initial setting value of 1. VER. SLOPE with the MENU $-/+$ key. 5. Adjust 1. VER. SLOPE to make "A = B" with the MENU $-/+$ key.
				
Adjustment of VER. POSITION	Signal generator Remote control unit		3. VER. POSITION	<ol style="list-style-type: none"> 6. Select 3. VER. POSITION with the MENU ∇/Δ key. 7. Set the initial setting value of 3. VER. POSITION with the MENU $-/+$ key. 8. Adjust 3. VER. POSITION to make "A = B" with the MENU $-/+$ key. <p>(to be continued)</p>
				




Item	Measuring instrument	Test point	Adjustment part	Description
Adjustment of V. ZOOM	Signal generator Remote control unit		2. VER. HEIGHT 13. V. ZOOM	<p>9. Receive a PAL cross-hatch signal.</p> <p>10. Select 2. VER. HEIGHT with the MENU ∇/Δ key.</p> <p>11. Set the initial setting value of 2. VER. HEIGHT with the MENU $-/+$ key.</p> <p>12. Select 13. V. ZOOM with the MENU ∇/Δ key.</p> <p>13. Set the initial setting value of 13. V. ZOOM with the MENU $-/+$ key.</p> <p>14. Adjust 13. V. ZOOM and make the vertical screen size 91% of the picture size with the MENU $-/+$ key.</p>
				
Adjustment of HOR. POSITION	Signal generator Remote control unit		5. HOR. POSITION	<p>15. Receive a PAL circle pattern signal.</p> <p>16. Select 5. HOR. POSITION with the MENU ∇/Δ key.</p> <p>17. Set the initial setting value of 5. HOR. POSITION with the MENU $-/+$ key.</p> <p>18. Adjust 5. HOR. POSITION to make "C=D" with the MENU $-/+$ key.</p>
				
Adjustment of HOR. WIDTH	Signal generator Remote control unit		6. HOR. WIDTH	<p>19. Receive a PAL cross-hatch signal.</p> <p>20. Select 6. HOR. WIDTH with the MENU ∇/Δ key.</p> <p>21. Set the initial setting value of 6. HOR. WIDTH with the MENU $-/+$ key.</p> <p>22. Adjust 6. HOR. WIDTH and make the horizontal screen size 91% of the picture size with the MENU $-/+$ key.</p>
				(to be continued)




Item	Measuring instrument	Test point	Adjustment part	Description
Adjustment of EW-PIN	Signal generator Remote control unit		7. EW-PIN	<p>23. Select 7. EW-PIN with the MENU ∇/Δ key.</p> <p>24. Set the initial setting value of 7. EW-PIN with the MENU $-/+$ key.</p> <p>25. Adjust 7. EW-PIN so that the first vertical lines at the left and right edges on the screen are straight.</p>
				
Adjustment of EW-TRAPEZ	Signal generator Remote control unit		8. EW-TRAPEZ	<p>26. Select 8. EW-TRAPEZ with the MENU ∇/Δ key.</p> <p>27. Set the initial setting value of 8. EW-TRAPEZ with the MENU $-/+$ key.</p> <p>28. Adjust 8. EW-TRAPEZ so that the vertical lines at the left and right edges on the screen are in parallel.</p>
				
Adjustment of VER. SCURVE	Signal generator Remote control unit		4. VER. SCURVE	<p>29. Select 4. VER. SCURVE with the MENU ∇/Δ key.</p> <p>30. Set the initial setting value of 4. VER. SCURVE with the MENU $-/+$ key.</p> <p>31. Adjust 4. VER. SCURVE so that the spaces of each line on TOP, CENTRE and BOTTOM become uniform.</p>
 <p>(to be continued)</p>				




Item	Measuring instrument	Test point	Adjustment part	Description
Adjustment of UP CORNER and DW CORNER	Signal generator Remote control unit		9. UP CORNER 10. DW CORNER	32. Select 9. UP CORNER with the MENU ∇/Δ key. 33. Set the initial setting value of 9. UP CORNER with the MENU $-/+$ key. 34. Select 10. DW CORNER with the MENU ∇/Δ key. 35. Set the initial setting value of 10. DW CORNER with the MENU $-/+$ key. 36. Adjust 9. UP CORNER and 10. DW CORNER so that the vertical lines at the four corners on the screen are straight.
Adjustment of HOR. PARALL	Signal generator Remote control unit		11. HOR. PARALL	37. Select 11. HOR. PARALL with the MENU ∇/Δ key. 38. Set the initial setting value of 11. HOR. PARALL with the MENU $-/+$ key. 39. Adjust 11. HOR. PARALL to optimize the parallelogram distortion.
Adjustment of HOR. BOW	Signal generator Remote control unit		12. HOR. BOW	40. Select 12. HOR. BOW with the MENU ∇/Δ key. 41. Set the initial setting value of Select 12. HOR. BOW with the MENU $-/+$ key. 42. Adjust 12. HOR. BOW to optimize the horizontal arc distortion. 43. Press the DISPLAY key twice to return to the normal screen.





[fv : 60Hz mode]

Item	Measuring instrument	Test point	Adjustment part	Description
Adjustment of VER. SLOPE	Signal generator Remote control unit		1. VER. SLOPE	<ol style="list-style-type: none"> 1. Receive a NTSC circle pattern signal of vertical frequency 60Hz. 2. Select 3. DEF from the SERVICE MENU. 3. Select 1. VER. SLOPE with the MENU ∇/Δ key. 4. Set the initial setting value of 1. VER. SLOPE with the MENU $-/+$ key. 5. Adjust 1. VER. SLOPE to make "A = B" with the MENU $-/+$ key.
				
Adjustment of VER.POSITION	Signal generator Remote control unit		3. VER. POSITION	<ol style="list-style-type: none"> 6. Select 3. VER. POSITION with the MENU ∇/Δ key. 7. Set the initial setting value of 3. VER. POSITION with the MENU $-/+$ key. 8. Adjust 3. VER. POSITION to make "A = B" with the MENU $-/+$ key.
				
Adjustment of V. ZOOM	Signal generator Remote control unit		2. VER. HEIGHT 13. V. ZOOM	<ol style="list-style-type: none"> 9. Receive a NTSC cross-hatch signal. 10. Select 2. VER. HEIGHT with the MENU ∇/Δ key. 11. Set the initial setting value of 2. VER. HEIGHT with the MENU $-/+$ key. 12. Select 13. V. ZOOM with the MENU ∇/Δ key. 13. Set the initial setting value of 13. V. ZOOM with the MENU $-/+$ key. 14. Adjust 13. V. ZOOM and make the vertical screen size 91% of the picture size with the MENU $-/+$ key.
				
				(to be continued)



Item	Measuring instrument	Test point	Adjustment part	Description
Adjustment of HOR. POSITION	Signal generator Remote control unit		5. HOR. POSITION	<p>15. Receive a NTSC circle pattern signal.</p> <p>16. Select 5. HOR. POSITION with the MENU ∇/Δ key.</p> <p>17. Set the initial setting value of 5. HOR. POSITION with the MENU $-/+$ key.</p> <p>18. Adjust 5. HOR. POSITION to make "C=D" with the MENU $-/+$ key.</p>
				
Adjustment of HOR. WIDTH	Signal generator Remote control unit		6. HOR. WIDTH	<p>19. Receive a NTSC cross-hatch signal.</p> <p>20. Select 6. HOR. WIDTH with the MENU ∇/Δ key.</p> <p>21. Set the initial setting value of 6. HOR. WIDTH with the MENU $-/+$ key.</p> <p>22. Adjust 6. HOR. WIDTH and make the horizontal screen size 91% of the picture size with the MENU $-/+$ key.</p>
				
Adjustment of EW-PIN	Signal generator Remote control unit		7. EW-PIN	<p>23. Select 7. EW-PIN with the MENU ∇/Δ key.</p> <p>24. Set the initial setting value of 7. EW-PIN with the MENU $-/+$ key.</p> <p>25. Adjust 7. EW-PIN so that the first vertical lines at the left and right edges on the screen are straight.</p>
				(to be continued)

Item	Measuring instrument	Test point	Adjustment part	Description
Adjustment of EW-TRAPEZ	Signal generator Remote control unit		8. EW-TRAPEZ 	26. Select 8. EW-TRAPEZ with the MENU ∇/Δ key. 27. Set the initial setting value of 8. EW-TRAPEZ with the MENU $-/+$ key. 28. Adjust 8. EW-TRAPEZ so that the vertical lines at the left and right edges on the screen are in parallel.
Adjustment of VER. SCURVE	Signal generator Remote control unit		4. VER. SCURVE 	29. Select 4. VER. SCURVE with the MENU ∇/Δ key. 30. Set the initial setting value of 4. VER. SCURVE with the MENU $-/+$ key. 31. Adjust 4. VER. SCURVE so that the spaces of each line on TOP, CENTRE and BOTTOM become uniform.
Adjustment of UP CORNER and DW CORNER	Signal generator Remote control unit		9. UP CORNER 10. DW CORNER	32. Select 9. UP CORNER with the MENU ∇/Δ key. 33. Set the initial setting value of 9. UP CORNER with the MENU $-/+$ key. 34. Select 10. DW CORNER with the MENU ∇/Δ key. 35. Set the initial setting value of 10. DW CORNER with the MENU $-/+$ key. 36. Adjust 9. UP CORNER and 10. DW CORNER so that the vertical lines at the four corners on the screen are straight.
Adjustment of HOR. PARALL	Signal generator Remote control unit		11. HOR. PARALL	37. Select 11. HOR. PARALL with the MENU ∇/Δ key. 38. Set the initial setting value of 11. HOR. PARALL with the MENU $-/+$ key. 39. Adjust 11. HOR. PARALL to optimize the parallelogram distortion.
Adjustment of HOR. BOW	Signal generator Remote control unit		12. HOR. BOW 	40. Select 12. HOR. BOW with the MENU ∇/Δ key. 41. Set the initial setting value of Select 12. HOR. BOW with the MENU $-/+$ key. 42. Adjust 12. HOR. BOW to optimize the horizontal arc distortion. 43. Press the DISPLAY key twice to return to the normal screen.

[COMPRESS (16 : 9), fv : 50Hz mode]

Item	Measuring instrument	Test point	Adjustment part	Description
Adjustment of V. ZOOM and VER. HEIGHT	Signal generator Remote control unit		13. V. ZOOM 2. VER. HEIGHT	<ol style="list-style-type: none"> 1. Receive a PAL cross-hatch signal of vertical frequency 50Hz. 2. Select COMPRESS from the MENU and set COMPRESS to ON. 3. Select 3. DEF from the SERVICE MENU. 4. Set the initial setting value of 13. V. ZOOM with the MENU \rightarrow/+ key. 5. Select 2. VER. HEIGHT with the MENU ∇/△ key. 6. Set the initial setting value of 2. VER. HEIGHT with the MENU \rightarrow/+ key. 7. Adjust 2. VER. HEIGHT to set the vertical amplitude of the image to 360mm.
				
Adjustment of EW-PIN	Signal generator Remote control unit		7. EW-PIN	<ol style="list-style-type: none"> 8. Select 7. EW-PIN with the MENU ∇/△ key. 9. Set the initial setting value of 7. EW-PIN with the MENU \rightarrow/+ key. 10. Adjust 7. EW-PIN so tha the first vertical lines at the left and right edges on the screen are straight.
				
Adjustment of UP CORNER and DW CORNER	Signal generator Remote control unit		9. UP CORNER 10. DW CORNER	<ol style="list-style-type: none"> 11. Select 9. UP CORNER with the MENU ∇/△ key. 12. Set the initial setting value of 9. UP CORNER with the MENU \rightarrow/+ key. 13. Select 10. DW CORNER with the MENU ∇/△ key. 14. Set the initial setting value of 10. DW CORNER with the MENU \rightarrow/+ key. 15. Adjust 9. UP CORNER and 10. DW CORNER so that the vertical lines at the four corners on the screen are straight. 16. Press the DISPLAY key twice to return to the normal screen.

[COMPRESS (16 : 9), fv : 60Hz mode]

Item	Measuring instrument	Test point	Adjustment part	Description
Adjustment of V. ZOOM and VER. HEIGHT	Signal generator Remote control unit		13. V. ZOOM 2. VER. HEIGHT	<ol style="list-style-type: none"> 1. Receive a NTSC cross-hatch signal of vertical frequency 60Hz. 2. Select COMPRESS from the MENU and set COMPRESS to ON. 3. Select 3. DEF from the SERVICE MENU. 4. Set the initial setting value of 13. V. ZOOM with the MENU \rightarrow/+ key. 5. Select 2. VER. HEIGHT with the MENU ∇/Δ key. 6. Set the initial setting value of 2. VER. HEIGHT with the MENU \rightarrow/+ key. 7. Adjust 2. VER. HEIGHT to set the vertical amplitude of the image to 360mm.
				
Adjustment of EW-PIN	Signal generator Remote control unit		7. EW-PIN	<ol style="list-style-type: none"> 8. Select 7. EW-PIN with the MENU ∇/Δ key. 9. Set the initial setting value of 7. EW-PIN with the MENU \rightarrow/+ key. 10. Adjust 7. EW-PIN so tha the first vertical lines at the left and right edges on the screen are straight.
				
Adjustment of UP CORNER and DW CORNER	Signal generator Remote control unit		9. UP CORNER 10. DW CORNER	<ol style="list-style-type: none"> 11. Select 9. UP CORNER with the MENU ∇/Δ key. 12. Set the initial setting value of 9. UP CORNER with the MENU \rightarrow/+ key. 13. Select 10. DW CORNER with the MENU ∇/Δ key. 14. Set the initial setting value of 10. DW CORNER with the MENU \rightarrow/+ key. 15. Adjust 9. UP CORNER and 10. DW CORNER so that the vertical lines at the four corners on the screen are straight. 16. Press the DISPLAY key twice to return to the normal screen.

PRESET ADJUSTMENT

- Do not adjust 5. PRESET in the SERVICE MENU as it requires no adjustment.

[SUB MENU 5. PRESET]

	Setting item	Variable range	Initial setting value
1	CB	0/1	0
2	ACL	0/1	0
3	MUS	0/1	0
4	MAT	0/1	0
5	FCO	0/1	0
6	BPS	0/1	0
7	IFLH	0/1	0
8	VID	0/1	0
9	STM	0/1	0
10	AFCW	0/1	0
11	VSW	0/1	0
12	FFI	0/1	0
13	AGC	00/10/01	10
14	CL	50 – 95	77
15	AKB	0/1	0
16	HBL	0/1	0
17	BKS	0/1	1
18	READ STATUS	—	—
19	VNR	00 – 63	25

AUDIO ADJUSTMENT [AV-34LS, AV-34LS-AU, AV-34LH]

- Do not adjust 6. AUDIO (1.ERROR LIMIT, 2.A2 ID THR, 3.SOUND SYSTEM) in the SERVICE MENU as it requires no adjustment.

[SUB MENU 6. AUDIO]


Setting item	Variable range	Initial setting value (fixed)
1. ERROR LIMIT (Do not adjust.)	000H — FF0H	100H
2. A2 ID THR (Do not adjust.)	00H — FFH	0AH
3. SOUND SYSTEM (Do not adjust.)	—	—

PURITY AND CONVERGENCE ADJUSTMENTS

Note: The final adjustment of CONVERGENCE must be done after the FOCUS adjustment. (CONVERGENCE is changed by FOCUS adjustment.)
When makes difference by FOCUS adjustment, should be reconfirming PURITY adjustment.

PURITY ADJUSTMENT

1. Demagnetize CRT with the demagnetizer.
2. Loosen the retainer screw of the deflection yoke.
3. Remove the wedges.
4. Input a green raster signal from the signal generator, and turn the screen to green raster.
5. Move the deflection yoke backward.
6. Bring the long lug of the purity magnets on the short lug and position them horizontally. (Fig. 2)
7. Adjust the gap between two lugs so that the GREEN RASTER will come into the centre of the screen. (Fig. 3)
8. Move the deflection yoke forward, and fix the position of the deflection yoke so that the whole screen will become green.
9. Insert the wedge to the top side of the deflection yoke so that it will not move.
10. Input a crosshatch signal.
11. Verify that the screen is horizontal.
12. Input red and blue raster signals, and make sure that purity is properly adjusted.



• P/C MAGNETS

P : PURITY MAGNET
4 : 4 POLES (convergence magnets)
6 : 6 POLES (convergence magnets)

Fig. 1




Fig. 2




Fig. 3

STATIC CONVERGENCE ADJUSTMENT

1. Input a crosshatch signal.
2. Using 4-pole convergence magnets, overlap the red and blue lines in the centre of the screen (Fig. 4) and turn them to magenta (red/blue).
3. Using 6-pole convergence magnets, overlap the magenta (red/blue) and green lines in the centre of the screen and turn them to white.
4. Repeat 2 and 3 above, and make best convergence.

DYNAMIC CONVERGENCE ADJUSTMENT

1. Using the Y_H VR on the deflection yoke, match the Y_H (CROSS). (Fig. 5 and 8)
2. Using the Y_V VR on the deflection yoke, match the Y_V . (Fig. 6 and 8)
3. Repeat the steps 1 and 2, obtain an optimum convergence.
4. Differential coil ADJUSTMENT.
In case where the horizontal lines of red and blue around the centre of both sides of the picture as shown in Fig. 7, adjust the X_v difference by using the differential coil on the top of the deflection yoke (Fig. 8) so as to minimize the X_v difference.

- After adjustment, fix the wedge at the original position.
Fasten the retainer screw of the deflection yoke.
Fix the 6 magnets with glue.




Fig. 8




Fig. 4




Fig. 5




Fig. 6




Fig. 7



VICTOR COMPANY OF JAPAN, LIMITED
HOME AV NETWORK BUSINESS UNIT 12, 3-chome, Moriya-cho, kanagawa-ku, Yokohama, kanagawa-prefecture, 221-8528, Japan

AV34LS-H #4 AV34LSAU-H #4 AV34LH-H #4
AV34LX-H #4 AV34LXA-H #4 AV3408TEE-H #4



Printed in Japan
VP0108
SW

JVC

SCHEMATIC DIAGRAMS

COLOUR TELEVISION

BASIC CHASSIS

CH


AV-34LS
AV-34LS_(-AU)
AV-34LH

AV-34LX
AV-34LX_(-A)
AV-3408TEE

CD-ROM No. SML200109




RM-C352-1C
[AV-34LS]
[AV-34LS_(-AU)]




RM-C353-1C
[AV-34LH]



RM-C355-1C
[AV-3408TEE]



RM-C357-1C
[AV-34LX]
[AV-34LX_(-A)]



AV-34LS AV-34LX AV-34LS(-AU) AV-34LX(-A) AV-34LH AV-3408TEE

STANDARD CIRCUIT DIAGRAM

■ NOTE ON USING CIRCUIT DIAGRAMS

1. SAFETY

The components identified by the \triangle symbol and shading are critical for safety. For continued safety replace safety critical components only with manufactures recommended parts.

2. SPECIFIED VOLTAGE AND WAVEFORM VALUES

The voltage and waveform values have been measured under the following conditions.

- (1) Input signal : Colour bar signal
- (2) Setting positions of each knob/button and variable resistor : Original setting position when shipped
- (3) Internal resistance of tester : DC 20k Ω /V
- (4) Oscilloscope sweeping time : H \Rightarrow 20 μ S/div
: V \Rightarrow 5mS/div
: Others \Rightarrow Sweeping time is specified.
- (5) Voltage values : All DC voltage values

* Since the voltage values of signal circuit vary to some extent according to adjustments, use them as reference values.

3. INDICATION OF PARTS SYMBOL [EXAMPLE]

- In the PW board : R1209 \rightarrow R209

4. INDICATIONS ON THE CIRCUIT DIAGRAM

(1) Resistors

• Resistance value

- No unit : [Ω]
- k : [k Ω]
- M : [M Ω]

• Rated allowable power

- No indication : 1/16 [W]
- Others : As specified

• Type

- No indication : Carbon resistor
- OMR : Oxide metal film resistor
- MFR : Metal film resistor
- MPR : Metal plate resistor
- UNFR : Non-Flammable resistor
- FR : Fusible resistor

* Composition resistor 1/2 [W] is specified as 1/2S or Comp.

(2) Capacitors

• Capacitance value

- 1 or higher : [pF]
- less than 1 : [μ F]

• Withstand voltage

- No indication : DC50[V]
- AC indicated : AC withstand voltage [V]
- Others : DC withstand voltage [V]

* Electrolytic Capacitors

47/50[Example] : Capacitance value [μ F]/withstand voltage[V]

• Type

- No indication : Ceramic capacitor
- MY : Mylar capacitor
- MM : Metalized mylar capacitor
- PP : Polypropylene capacitor
- MPP : Metalized polypropylene capacitor
- MF : Metalized film capacitor
- TF : Thin film capacitor
- BP : Bipolar electrolytic capacitor
- TAN : Tantalum capacitor

(3) Coils



- No unit : [μ H]
- Others : As specified

(4) Power Supply




-  : B1
-  : B2(12V)
-  : 9V
-  : 5V

* Respective voltage values are indicated





(5) Test point

-  : Test point
-  : Only test point display

(6) Connecting method

-  : Connector
-  : Wrapping or soldering
-  : Receptacle

(7) Ground symbol

-  : LIVE side ground
-  : ISOLATED(NEUTRAL) side ground
-  : EARTH ground
-  : DIGITAL ground

5. NOTE FOR REPAIRING SERVICE

This model's power circuit is partly different in the GND. The difference of the GND is shown by the LIVE : (\perp) side GND and the ISOLATED(NEUTRAL) : (\nearrow) side GND. Therefore, care must be taken for the following points.

- (1) Do not touch the LIVE side GND or the LIVE side GND and the ISOLATED(NEUTRAL) side GND simultaneously. If the above caution is not respected, an electric shock may be caused. Therefore, make sure that the power cord is surely removed from the receptacle when, for example, the chassis is pulled out.
- (2) Do not short between the LIVE side GND and ISOLATED(NEUTRAL) side GND or never measure with a measuring apparatus (oscilloscope, etc.) the LIVE side GND and ISOLATED(NEUTRAL) side GND at the same time. If the above precaution is not respected , a fuse or any parts will be broken.

• Since the circuit diagram is a standard one, the circuit and circuit constants may be subject to change for improvement without any notice.

CONTENTS

SEMICONDUCTOR SHAPES 2-2

BLOCK DIAGRAM 2-3

CIRCUIT DIAGRAMS

<div><div></div><div>Model</div></div> <div>P.W.B. name</div>	AV-34LS AV-34LS-AU AV-34LH	AV-34LX AV-34LX-A AV-3408TEE
MAIN PWB CIRCUIT DIAGRAM (1/2)	P2-5	P2-7
MAIN PWB CIRCUIT DIAGRAM (2/2)	P2-9	P2-11
CRT SOCKET PWB CIRCUIT DIAGRAM	P2-13	←
FRONT CONTROL PWB CIRCUIT DIAGRAM	P2-15	←

PATTERN DIAGRAMS

<div><div></div><div>Model</div></div> <div>Patten name</div>	AV-34LS AV-34LS-AU AV-34LH	AV-34LX AV-34LX-A AV-3408TEE
MAIN PWB PATTERN	P2-17	←
CRT SOCKET PWB PATTERN	P2-19	←
FRONT CONTROL PWB PATTERN	P2-20	←

SEMICONDUCTOR SHAPES

TRANSISTOR

BOTTOM VIEW	FRONT VIEW				TOP VIEW
					CHIP TR

IC

BOTTOM VIEW	FRONT VIEW			TOP VIEW


CHIP IC

TOP VIEW		

AV-34LS AV-34LH
AV-34LX AV-3408TEE

AV-34LS AV-34LH
AV-34LX AV-3408TEE

BLOCK DIAGRAM



No.51854

2-3

2-4


No.51854

CIRCUIT DIAGRAMS

MAIN PWB CIRCUIT DIAGRAM (1/2) [AV-34LS, AV-34LS-AU, AV-34LH]

AV-34LS
AV-34LH

AV-34LS
AV-34LH




MAIN PWB ASS'Y (1/2)
SCH-1007A-H2 (AV-34LS)
SCH-1036A-H2 (AV-34LH)
SCH-1037A-H2 (AV-34LS-AU)

* DIFFERENCE LIST (*PARTS)

	IC701	J801	R801	R802	R817	R819	C806	C809
SCH-1007A-H2	TDA9365N13S0455	QNN0349-001	NOT USED	NOT USED	NOT USED	NOT USED	NOT USED	NOT USED
SCH-1036A-H2	TDA9386N12S0450	QNN0349-001	NOT USED	NOT USED	NOT USED	NOT USED	NOT USED	NOT USED
SCH-1037A-H2	TDA9365N13S0455	QNZ0454-001	75Ω	75Ω	100Ω	100Ω	0.1μF	0.01μF

NOTE
X : OPTION (NON MOUNT)
BW : BUS WIRE
*2 : 2SA1037AK/QR-X
*3 : MA111-X
*5 : DTC124EKA-X
*7 : 2SC1740S/QR-T

MAIN PWB CIRCUIT DIAGRAM (1/2) [AV-34LX, AV-34LX-A, AV-3408TEE]



MAIN PWB ASS'Y (1/2)
SCH-1008A-H2 (AV-34LX, AV-34LX-A)
SCH-1038A-H2 (AV-3408TEE)

* DIFFERENCE LIST (*PARTS)


	IC701
SCH-1008A-H2	TDA9386N12S0450
SCH-1038A-H2	TDA9365N13S0455

NOTE
X : OPTION (NON MOUNT)
BW : BUS WIRE
*2 : 2SA1037AK/QR-X
*3 : MA111-X
*5 : DTC124EKA-X
*7 : 2SC1740S/QR-T

AV-34LS
AV-34LH

AV-34LS
AV-34LH


MAIN PWB CIRCUIT DIAGRAM (2/2) [AV-34LS, AV-34LS-AU, AV-34LH]



AV-34LX
AV-3408TEE


AV-34LX
AV-3408TEE

MAIN PWB CIRCUIT DIAGRAM (2/2) [AV-34LX, AV-34LX-A, AV-3408TEE]



AV-34LS AV-34LX AV-34LH AV-3408TEE

CRT SOCKET PWB CIRCUIT DIAGRAM




FRONT CONTROL PWB ASS'Y
SCH-8002A-H2
 (AV-34LS, AV-34LS-AU, AV-34LH,
 AV-34LX, AV-34LX-A, AV-3408TEE)


NOTE
 X : OPTION (NON MOUNT)
 BW : BUS WIRE
 *1 : 2SC2412K/QR-X
 *2 : 2SA1037AK/QR-X
 *3 : MA1111-X

PATTERN DIAGRAMS

MAIN PWB PATTERN



CRT SOCKET PWB PATTERN




(H)


AV-34LS AV-34LX
AV-34LH AV-3408TEE

FRONT CONTROL PWB PATTERN

— FRONT CONTROL (1/2) —



— FRONT CONTROL (2/2) —





VICTOR COMPANY OF JAPAN, LIMITED
HOME AV NETWORK BUSINESS UNIT 12, 3-chome, Moriya-cho, kanagawa-ku, Yokohama, kanagawa-prefecture, 221-8528, Japan

AV34LS-H #4 AV34LSAU-H #4 AV34LH-H #4
AV34LX-H #4 AV34LXA-H #4 AV3408TEE-H #4



Printed in Japan
VP0108
SW

PARTS LIST

CAUTION

- The parts identified by the \triangle symbol are important for the safety . Whenever replacing these parts, be sure to use specified ones to secure the safety .
- The parts not indicated in this Parts List and those which are filled with lines --- in the Parts No. columns will not be supplied .
- P. W. Board Ass'y will not be supplied, but those which are filled with the Parts No. in the Parts No. columns will be supplied .

ABBREVIATIONS OF RESISTORS, CAPACITORS AND TOLERANCES

RESISTORS		CAPACITORS	
C R	Carbon Resistor	C CAP.	Ceramic Capacitor
F R	Fusible Resistor	E CAP.	Electrolytic Capacitor
P R	Plate Resistor	M CAP.	Mylar Capacitor
V R	Variable Resistor	HV CAP.	High Voltage Capacitor
HV R	High Voltage Resistor	MF CAP.	Metalized Film Capacitor
MF R	Metal Film Resistor	MM CAP.	Metalized Mylar Capacitor
MG R	Metal Glazed Resistor	MP CAP.	Metalized Polystyrol Capacitor
MP R	Metal Plate Resistor	PP CAP.	Polypropylene Capacitor
OM R	Metal Oxide Film Resistor	PS CAP.	Polystyrol Capacitor
CMF R	Coating Metal Film Resistor	TF CAP.	Thin Film Capacitor
UNF R	Non-Flammable Resistor	MPP CAP.	Metalized Polypropylene Capacitor
CH V R	Chip Variable Resistor	TAN. CAP.	Tantalum Capacitor
CH MG R	Chip Metal Glazed Resistor	CH C CAP.	Chip Ceramic Capacitor
COMP. R	Composition Resistor	BP E CAP.	Bi-Polar Electrolytic Capacitor
LPTC R	Linear Positive Temperature Coefficient Resistor	CH AL E CAP.	Chip Aluminum Electrolytic Capacitor
		CH AL BP CAP.	Chip Aluminum Bi-Polar Capacitor
		CH TAN. E CAP.	Chip Tantalum Electrolytic Capacitor
		CH AL BP E CAP.	Chip Tantalum Bi-Polar Electrolytic Capacitor

RESISTORS									
F	G	J	K	M	N	R	H	Z	P
±1%	±2%	±5%	±10%	±20%	±30%	+30% -10%	+50% -10%	+80% -20%	+100% 0%

CONTENTS

USING P.W. BOARD & REMOTE CONTROL UNIT	39
EXPLODED VIEW PARTS LIST-I	39
EXPLODED VIEW-I	39
EXPLODED VIEW PARTS LIST-II	40
EXPLODED VIEW-II	41

PRINTED WIRING BOARD PARTS LIST (AV-34LS)

MAIN PW BOARD ASS'Y	42
CRT SOCKET PW BOARD ASS'Y	46
FRONT CONTROL PW BOARD ASS'Y	47
DIFFERENCE PARTS LIST BETWEEN AV-34LS, AV-34LS-AU AND AV-34LH	48

PRINTED WIRING BOARD PARTS LIST (AV-34LX)

MAIN PW BOARD ASS'Y	49
CRT SOCKET PW BOARD ASS'Y	53
FRONT CONTROL PW BOARD ASS'Y	53
DIFFERENCE PARTS LIST BETWEEN AV-34LX, AV-34LX-A AND AV-3408TEE	54

REMOTE CONTROL UNIT PARTS LIST

(AV-34LS, AV-34LS-AU, AV-34LH, AV-34LX, AV-34LX-A AND AV-3408TEE).....	54
---	-----------

PACKING / PACKING PARTS LIST	55
---	-----------

USING P.W. BOARD & REMOTE CONTROL UNIT


P.W.B ASS'Y \ Model	AV-34LS	AV-34LS-AU	AV-34LH
MAIN PWB	SCH-1007A-H2	SCH-1037A-H2	SCH-1036A-H2
CRT SOCKET PWB	SCH-3002A-H2	←	←
FRONT CONTROL PWB	SCH-8002A-H2	←	←
REMOTE CONTROL UNIT	RM-C352-1C	←	RM-C353-1C

P.W.B ASS'Y \ Model	AV-34LX	AV-34LX-A	AV-3408TEE
MAIN PWB	SCH-1008A-H2	←	SCH-1038A-H2
CRT SOCKET PWB	SCH-3002A-H2	←	←
FRONT CONTROL PWB	SCH-8002A-H2	←	←
REMOTE CONTROL UNIT	RM-C357-1C	←	RM-C355-1C

EXPLODED VIEW PARTS LIST-I

△ Ref.No.	Part No.	Part Name	Description	Local
23	LC20778-004A-H	OPERATION SHEET		
24	LC31474-001A-H	CONTROL WINDOW		
25	LC31476-001B-H	LED LENS		
26	LC41037-001A	JVC MARK		
101	LC11231-002B-H	FRONT CABI ASSY	Inc.No.102-106 [AV-34LS,AV-34LS-AU]	
101	LC11231-003A-H	FRONT CABI ASSY	Inc.No.102-106 [AV-34LH]	
101	LC11231-004B-H	FRONT CABI ASSY	Inc.No.102-106 [AV-34LX,AV-LX-A]	
101	LC11231-007A-H	FRONT CABI ASSY	Inc.No.102-106 [AV-3408TEE]	
102	LC20776-001B-H	DOOR	[AV-34LS,AV-34LS-AU]	
102	LC20776-002A-H	DOOR	[AV-34LH]	
102	LC20776-003A-H	DOOR	[AV-34LX,AV-34LX-A]	
102	LC20776-004A-H	DOOR	[AV-3408TEE]	
103	CM48229-00A-C	DOOR LATCH		
104	LC20777-001D-H	CENTRE PLATE		
105	LC31475-001B-H	POWER KNOB		
106	CM35235-003-H	SPRING		


EXPLODED VIEW-I



EXPLODED VIEW PARTS LIST-II

△ Ref.No.	Part No.	Part Name	Description	Local
△ V01	A80LTM350X	PICTURE TUBE		
△ L01	QQW0121-001	DEG COIL		
△ DY01	QDD0065-001	DEF YOKE		
△ T1551	QQH0096-001	FBT		
△ 1	QMP40D0-200J5	POWER CORD	[AV-34LS,AV-34LX,AV-3408TEE]	
△ 1	QMPN050-200-E2	POWER CORD	[AV-34LH]	
△ 1	QMP2980-185J5	POWER CORD	[AV-34LS-AU]	
△ 1	QMPR010-200-E2	POWER CORD	[AV-34LX-A]	
△ 2	CM23167-A01-H	CORD CLAMP		
3	WJY0018-002A	BRAIDED ASSY		
4	CHGB0017-0C	BRAIDED SUB ASSY	(X2)	
5	A48457-3-H	SPRING		
6	LC11100-001A-H	SP HOLDER	(X2)	
7	QAS0083-001	SPEAKER	(X2) SP01, SP02	
8	QYSBSFG4016Z	TAPPING SCREW	(X8)	
△ 9	LC10180-004A-HH	REAR COVER	[AV-34LS,AV-34LX,AV-34LX-A,AV-3408TEE]	
△ 9	LC10180-006A-H	REAR COVER	[AV-34LH,AV-34LS-AU]	
10	QYSBSFG4016Z	TAPPING SCREW	(X18)	
△ 11	LC20377-001B-H	RATING LABEL	[AV-34LS]	
△ 11	LC20377-012B-H	RATING LABEL	[AV-34LH]	
△ 11	LC20377-013B-H	RATING LABEL	[AV-34LS-AU]	
△ 11	LC20377-010B-H	RATING LABEL	[AV-34LX]	
△ 11	LC20413-002B-H	RATING LABEL	[AV-34LX-A]	
△ 11	LC20377-009B-H	RATING LABEL	[AV-3408TEE]	
12	CHFD125-18BD-N	FFC WIRE		
13	LC11064-002A-H	AV TERMINAL BOARD	[AV-34LS,AV-34LH,AV-34LX,AV-34LX-A,AV-3408TEE]	
13	LC11064-001B-H	AV TERMINAL BOARD	[AV-34LS-AU]	
14	QYSBSF3012M	TAPPING SCREW	(X4)	
15	LC11061-001A-H	CHASSIS BASE		
16	LC11062-001C-H	CONTROL BASE		
17	LC40226-003A-H	SPACER	(X4)	
18	LC40573-002A-H	WASHER	(X4)	
19	LC40317-002A-H	TAPPING SCREW	(X4)	
20	CE42735-00A	PC MAGNET		
21	CE41488-00A	WEDGE ASSY	(X4)	
22	LC30103-001B-H	CHASSIS ADAPTER	(X2)	

EXPLODED VIEW-II



PRINTED WIRING BOARD PARTS LIST (AV-34LS)

MAIN PW BOARD ASS'Y (SCH-1007A-H2)

△ Symbol No.	Part No.	Part Name	Description	Local	△ Symbol No.	Part No.	Part Name	Description	Local
RESISTOR					RESISTOR				
R1001-02	NRSA63J-221X	MG R	220Ω 1/16W J		R1542	QRE121J-104Y	C R	100kΩ 1/2W J	
R1003	NRSA63J-392X	MG R	3.9kΩ 1/16W J		R1543	QRE121J-471Y	C R	470Ω 1/2W J	
R1004	NRSA63J-221X	MG R	220Ω 1/16W J		R1545	QRE121J-220Y	C R	22Ω 1/2W J	
R1006	NRSA63J-273X	MG R	27kΩ 1/16W J		R1546	QRE121J-822Y	C R	8.2kΩ 1/2W J	
R1101	NRSA63J-100X	MG R	10Ω 1/16W J		R1561	QRL02EJ-220X	CMF R	22Ω 2W J	
R1102	NRSA63J-682X	MG R	6.8kΩ 1/16W J		R1562	QRE121J-123Y	C R	12kΩ 1/2W J	
R1103	NRSA63J-272X	MG R	2.7kΩ 1/16W J		R1563	QRZ0056-103Z	COMP R	10kΩ 1/2W K	
R1104	NRSA63J-181X	MG R	180Ω 1/16W J		R1564-68	QRE121J-184Y	C R	180kΩ 1/2W J	
R1105	NRSA63J-100X	MG R	10Ω 1/16W J		R1571	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
R1106	NRSA63J-101X	MG R	100Ω 1/16W J		R1578	NRSA63J-102X	MG R	1kΩ 1/16W J	
R1107	NRSA63J-472X	MG R	4.7kΩ 1/16W J		R1580	NRSA63J-392X	MG R	3.9kΩ 1/16W J	
R1108-10	NRSA63J-222X	MG R	2.2kΩ 1/16W J		R1581	NRSA63J-183X	MG R	18kΩ 1/16W J	
R1111	NRSA63J-102X	MG R	1kΩ 1/16W J		R1582	NRSA63J-392X	MG R	3.9kΩ 1/16W J	
R1112	NRSA63J-103X	MG R	10kΩ 1/16W J		R1583	NRSA63J-183X	MG R	18kΩ 1/16W J	
R1113	NRSA63J-271X	MG R	270Ω 1/16W J		R1584	NRSA63J-152X	MG R	1.5kΩ 1/16W J	
R1114	NRSA63J-821X	MG R	820Ω 1/16W J		R1591	QRA14CF-1202Y	MF R	12kΩ 1/4W F	
R1115	NRSA63J-181X	MG R	180Ω 1/16W J		R1592	QRZ0221-2R2	UNF R	2.2Ω	
R1117	NRSA63J-102X	MG R	1kΩ 1/16W J		R1593	NRSA02F-332X	MG R	3.3kΩ 1/10W F	
R1119	NRSA63J-102X	MG R	1kΩ 1/16W J		R1594	QRE121J-183Y	C R	18kΩ 1/2W J	
R1120	NRSA63J-471X	MG R	470Ω 1/16W J		R1595	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1150	NRSA63J-331X	MG R	330Ω 1/16W J		R1602	NRSA63J-271X	MG R	270Ω 1/16W J	
R1151	NRSA63J-222X	MG R	2.2kΩ 1/16W J		R1603-04	NRSA63J-101X	MG R	100Ω 1/16W J	
R1152	NRSA63J-121X	MG R	120Ω 1/16W J		R1634-35	QRE141J-222Y	C R	2.2kΩ 1/4W J	
R1153	NRSA63J-122X	MG R	1.2kΩ 1/16W J		R1650	NRSA63J-223X	MG R	22kΩ 1/16W J	
R1154	NRSA63J-181X	MG R	180Ω 1/16W J		R1651	NCF31AZ-105X	C CAP.	1μF 10V Z	
R1301-02	NRSA63J-222X	MG R	2.2kΩ 1/16W J		R1654	NRSA63J-223X	MG R	22kΩ 1/16W J	
R1303	NRSA63J-562X	MG R	5.6kΩ 1/16W J		R1655	NCF31AZ-105X	C CAP.	1μF 10V Z	
R1304-05	NRSA63J-222X	MG R	2.2kΩ 1/16W J		R1658-59	QRE121J-2R2Y	C R	2.2Ω 1/2W J	
R1306	NRSA63J-562X	MG R	5.6kΩ 1/16W J		R1660	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1307	NRSA63J-103X	MG R	10kΩ 1/16W J		R1661	NRSA63J-683X	MG R	68kΩ 1/16W J	
R1308	NRSA63J-101X	MG R	100Ω 1/16W J		R1662	NRSA63J-333X	MG R	33kΩ 1/16W J	
R1309	NRSA63J-104X	MG R	100kΩ 1/16W J		R1663	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1310	NRSA63J-473X	MG R	47kΩ 1/16W J		R1664	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1311	NRSA63J-123X	MG R	12kΩ 1/16W J		R1665-66	QRE141J-392Y	C R	3.9kΩ 1/4W J	
R1401	NRSA63J-224X	MG R	220kΩ 1/16W J		R1667	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1403	NRSA63J-0R0X	MG R	0.0Ω 1/16W J		R1668	NRSA63J-683X	MG R	68kΩ 1/16W J	
R1405	NRSA63J-682X	MG R	6.8kΩ 1/16W J		R1669	NRSA63J-563X	MG R	56kΩ 1/16W J	
R1406	NRSA63J-472X	MG R	4.7kΩ 1/16W J		R1670	NRSA63J-153X	MG R	15kΩ 1/16W J	
R1408	NRSA63J-682X	MG R	6.8kΩ 1/16W J		R1671	NRSA63J-272X	MG R	2.7kΩ 1/16W J	
R1410	NRSA63J-472X	MG R	4.7kΩ 1/16W J		R1672	NRSA63J-563X	MG R	56kΩ 1/16W J	
R1411	QRG01GJ-221	OM R	220Ω 1W J		R1673-74	NRSA63J-683X	MG R	68kΩ 1/16W J	
R1412	QRE121J-1R0Y	C R	1.0Ω 1/2W J		R1675	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1413	QRX01GJ-1R2	MF R	1.2Ω 1W J		R1676-77	NRSA63J-472X	MG R	4.7kΩ 1/16W J	
R1414	QRE121J-1R8Y	C R	1.8Ω 1/2W J		R1678	NRSA63J-153X	MG R	15kΩ 1/16W J	
R1425	NRSA63J-683X	MG R	68kΩ 1/16W J		R1679	NRSA63J-272X	MG R	2.7kΩ 1/16W J	
R1478-79	NRSA63J-101X	MG R	100Ω 1/16W J		R1680	NRSA63J-683X	MG R	68kΩ 1/16W J	
R1480	QRE121J-681Y	C R	680Ω 1/2W J		R1688	NRSA63J-273X	MG R	27kΩ 1/16W J	
R1481	NRSA63J-223X	MG R	22kΩ 1/16W J		R1690	NRSA63J-104X	MG R	100kΩ 1/16W J	
R1482	NRSA63J-562X	MG R	5.6kΩ 1/16W J		R1691	NRSA63J-682X	MG R	6.8kΩ 1/16W J	
R1483	NRSA63J-823X	MG R	82kΩ 1/16W J		R1692	NRSA63J-104X	MG R	100kΩ 1/16W J	
R1484	NRSA63J-562X	MG R	5.6kΩ 1/16W J		R1693	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1485	NRSA63J-123X	MG R	12kΩ 1/16W J		R1696	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1486	NRSA63J-272X	MG R	2.7kΩ 1/16W J		R1701	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1487	NRSA63J-333X	MG R	33kΩ 1/16W J		R1702-03	NRSA63J-101X	MG R	100Ω 1/16W J	
R1489	NRSA63J-122X	MG R	1.2kΩ 1/16W J		R1704-06	NRSA63J-102X	MG R	1kΩ 1/16W J	
R1490	NRSA63J-102X	MG R	1kΩ 1/16W J		R1707-10	NRSA63J-472X	MG R	4.7kΩ 1/16W J	
R1491	NRSA63J-562X	MG R	5.6kΩ 1/16W J		R1711-14	NRSA63J-101X	MG R	100Ω 1/16W J	
R1492	NRSA63J-822X	MG R	8.2kΩ 1/16W J		R1715-17	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1493	QRE121J-223Y	C R	22kΩ 1/2W J		R1718-19	NRSA63J-221X	MG R	220Ω 1/16W J	
R1494	QRL03EJ-330X	OM R	33Ω 3W J		R1720	NRSA63J-102X	MG R	1kΩ 1/16W J	
R1521	NRSA63J-101X	MG R	100Ω 1/16W J		R1721-24	NRSA63J-221X	MG R	220Ω 1/16W J	
R1522	NRSA63J-102X	MG R	1kΩ 1/16W J		R1725	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1523	QRL03EJ-181X	OM R	180Ω 3W J		R1726	NRSA63J-472X	MG R	4.7kΩ 1/16W J	
R1524	QRL03EJ-181X	OM R	180Ω 3W J		R1727	NRSA63J-104X	MG R	100kΩ 1/16W J	
R1526	QRL029J-271	OM R	270Ω 2W J		R1728	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1527	QRL03EJ-103X	OM R	10kΩ 3W J		R1730	NRSA63J-223X	MG R	22kΩ 1/16W J	
R1528	QRX029J-3R3	MF R	3.3Ω 2W J		R1731	NRSA63J-101X	MG R	100Ω 1/16W J	
R1529	QRX029J-3R3	MF R	3.3Ω 2W J		R1732	NRSA02F-393X	MF R	39kΩ 2W F	
R1531	NRSA63J-182X	MG R	1.8kΩ 1/16W J		R1733	NRSA63J-273X	MG R	27kΩ 1/16W J	
△ R1532	QRZ9017-4R7	F R	4.7Ω 1/4W J		R1734	NRSA63J-391X	MG R	390Ω 1/16W J	
R1540	QRZ9011-4R7	F R	4.7Ω 1/2W J		R1735	NRSA63J-104X	MG R	100kΩ 1/16W J	
R1541	QRE121J-124Y	C R	120kΩ 1/2W J		R1736	NRSA63J-333X	MG R	33kΩ 1/16W J	

△ Symbol No.	Part No.	Part Name	Description	Local
RESISTOR				
R1737	NRSA63J-272X	MG R	2.7kΩ 1/16W J	
R1738	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1739-41	NRSA63J-101X	MG R	100Ω 1/16W J	
R1742	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
R1744	NRSA63J-561X	MG R	560Ω 1/16W J	
R1745	NRSA63J-105X	MG R	1MΩ 1/16W J	
R1746	NRSA63J-333X	MG R	33kΩ 1/16W J	
R1747	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1748	QRE141J-394Y	C R	390kΩ 1/4W J	
R1749	QRE141J-334Y	C R	330kΩ 1/4W J	
R1755-56	NRSA63J-101X	MG R	100Ω 1/16W J	
R1757-58	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1803	NRSA63J-333X	MG R	33kΩ 1/16W J	
R1804-07	NRSA63J-750X	MG R	75Ω 1/16W J	
R1808	NRSA63J-823X	MG R	82kΩ 1/16W J	
R1809	NRSA63J-391X	MG R	390Ω 1/16W J	
R1810	NRSA63J-823X	MG R	82kΩ 1/16W J	
R1811	NRSA63J-391X	MG R	390Ω 1/16W J	
R1812	NRSA63J-104X	MG R	100kΩ 1/16W J	
R1813	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1815	NRSA63J-101X	MG R	100Ω 1/16W J	
R1818	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1820	NRSA63J-101X	MG R	100Ω 1/16W J	
R1821	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1823	NRSA63J-101X	MG R	100Ω 1/16W J	
R1824	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1826	NRSA63J-101X	MG R	100Ω 1/16W J	
R1830-31	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1832	QRE141J-391Y	C R	390Ω 1/4W J	
R1833	NRSA63J-331X	MG R	330Ω 1/16W J	
R1834-35	NRSA63J-562X	MG R	5.6kΩ 1/16W J	
R1836	NRSA63J-750X	MG R	75Ω 1/16W J	
R1837	NRSA63J-101X	MG R	100Ω 1/16W J	
R1838	QRK126J-121X	C R	120Ω 1/2W J	
R1839-40	QRE121J-221Y	C R	220Ω 1/2W J	
R1841-42	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
R1843	NRSA63J-821X	MG R	820Ω 1/16W J	
R1844	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1845	NRSA63J-102X	MG R	1kΩ 1/16W J	
R1846	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1847	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1848	NRSA63J-221X	MG R	220Ω 1/16W J	
R1849	NRSA63J-471X	MG R	470Ω 1/16W J	
R1880	NRSA63J-202X	MG R	2kΩ 1/16W J	
R1881	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1882	NRSA63J-181X	MG R	180Ω 1/16W J	
R1883	NRSA63J-471X	MG R	470Ω 1/16W J	
R1902	QRF154K-2R2	UNF R	2.2Ω K	
R1903	QRL039J-473	OM R	47kΩ 3W J	
R1904	QRE121J-681Y	C R	680Ω 1/2W J	
R1905	QRM034J-R10	MP R	0.1Ω 3W J	
R1908	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1909	QRE121J-274Y	C R	270kΩ 1/2W J	
R1911	QRE121J-472Y	C R	4.7kΩ 1/2W J	
R1912	QRE121J-222Y	C R	2.2kΩ 1/2W J	
△ R1913	QRZ9017-4R7	F R	4.7Ω 1/4W J	
R1914	QRL039J-473	OM R	47kΩ 3W J	
R1915	QRE121J-394Y	C R	390kΩ 1/2W J	
R1916	QRE121J-332Y	C R	3.3kΩ 1/2W J	
R1917	NRSA63J-101X	MG R	100Ω 1/16W J	
R1918	NRSA63J-224X	MG R	220kΩ 1/16W J	
R1919	NRSA63J-104X	MG R	100kΩ 1/16W J	
R1920	NRSA63J-473X	MG R	47kΩ 1/16W J	
R1921	QRE121J-563Y	C R	56kΩ 1/2W J	
R1951	QRE121J-223Y	C R	22kΩ 1/2W J	
R1952	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1953	QRE121J-152Y	C R	1.5kΩ 1/2W J	
R1955	QRG01GJ-470	OM R	47Ω 1W J	
R1957	QRE121J-5R6Y	C R	5.6Ω 1/2W J	
R1958	QRL039J-820	OM R	82Ω 3W J	
R1959	QRE121J-820Y	C R	82Ω 1/2W J	
R1960	NRSA63J-391X	MG R	390Ω 1/16W J	

△ Symbol No.	Part No.	Part Name	Description	Local
RESISTOR				
R1961	QRL02EJ-223X	OM R	22kΩ 2W J	
R1963	QRE121J-332Y	C R	3.3kΩ 1/2W J	
R1964	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1965	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
R1966	NRSA63J-682X	MG R	6.8kΩ 1/16W J	
R1967	NRSA63J-473X	MG R	47kΩ 1/16W J	
R1969	QRT02EJ-2R7X	MF R	2.7Ω 2W J	
R1970	NRSA63J-153X	MG R	15kΩ 1/16W J	
R1971	NRSA63J-183X	MG R	18kΩ 1/16W J	
△ R1991	QRZ0057-825	C R	8.2MΩ 1W J	
CAPACITOR				
C1001	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1002	QETN1HM-106Z	E CAP.	10μF 50V M	
C1003	QFV71HJ-104Z	MF CAP.	0.1μF 50V J	
C1004	QETN1CM-477Z	E CAP.	470μF 16V M	
C1005	NCB31HK-222X	C CAP.	2200pF 50V K	
C1006	QETN1CM-336Z	E CAP.	33μF 16V M	
C1007	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1101-05	NCB31HK-472X	C CAP.	4700pF 50V K	
C1106-07	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1108	NCB31HK-472X	C CAP.	4700pF 50V K	
C1109	QETN1HM-106Z	E CAP.	10μF 50V M	
C1150-51	NCB31HK-472X	C CAP.	4700pF 50V K	
C1301-02	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1304-05	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1306	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1307	NDC31HJ-330X	C CAP.	33pF 50V J	
C1308	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1401	QETN1HM-105Z	E CAP.	1μF 50V M	
C1402	QCB31HK-682Z	C CAP.	6800pF 50V K	
C1403	QEHR1VM-107Z	E CAP.	100μF 35V M	
C1411-12	NCF21HZ-334X	C CAP.	0.33μF 50V Z	
C1413	QFLC2AJ-563Z	M CAP.	0.056μF 100V J	
C1422	QEHR1VM-108Z	E CAP.	1000μF 35V M	
C1471	QETN1HM-106Z	E CAP.	10μF 50V M	
C1480	QETN1HM-106Z	E CAP.	10μF 50V M	
C1483	QEZO195-475Z	E CAP.	4.7μF 50V M	
C1485	QETN1HM-226Z	E CAP.	22μF 50V M	
C1521	QETN1VM-476Z	E CAP.	47μF 35V M	
C1522	QFLC1HJ-332Z	M CAP.	3300pF 50V J	
C1523	QFLC1HJ-223Z	M CAP.	0.022μF 50V J	
C1524	QFZO200-372	MPP CAP.	3700pF 1.5kVH ±3%	
C1525	QFZO200-123	MPP CAP.	0.012μF 1.5kVH ±3%	
C1526	QFP32JJ-223	PP CAP.	0.022μF 630V J	
C1527	QFZO199-184	MPP CAP.	0.18μF 250V J	
C1528	QFZO199-204	MPP CAP.	0.2μF 250V J	
C1529	QENC2AM-225Z	BP E CAP.	2.2μF 100V M	
C1530	QCB32HK-561Z	C CAP.	560pF 500V K	
C1531	QEHR1EM-108Z	E CAP.	1000μF 25V M	
C1532	QCB32HK-561Z	C CAP.	560pF 500V K	
C1533	QEHR1EM-108Z	E CAP.	1000μF 25V M	
C1534	QCB32HK-561Z	C CAP.	560pF 500V K	
C1536	QFLC1HJ-103Z	M CAP.	0.01μF 50V J	
C1540	QFV71HJ-104Z	MF CAP.	0.1μF 50V J	
C1541	QETN2EM-106Z	E CAP.	10μF 250V M	
C1542	QFZO128-473	MPP CAP.	0.047μF 400V ±3%	
C1550	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1561	QFV11HJ-683Z	TF CAP.	0.068μF 50V J	
C1563-64	QCZO122-471	C CAP.	470pF 2000V K	
C1565	QFZO122-682	MPP CAP.	6800pF 1.8kVH ±3%	
C1566	QFZO200-113	MPP CAP.	0.011μF 1.5kVH ±3%	
C1571	QETN1CM-476Z	E CAP.	47μF 16V M	
C1575	QETN1EM-476Z	E CAP.	47μF 25V M	
C1591	QETN1AM-107Z	E CAP.	100μF 10V M	
C1592	QETM2CM-227	E CAP.	220μF 160V M	
C1593	QETN1EM-476Z	E CAP.	47μF 25V M	
C1602	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1603	QETN1CM-107Z	E CAP.	100μF 16V M	
C1604	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1606-07	NDC31HJ-2R0X	C CAP.	2.0pF 50V J	
C1608-09	NCB31HK-103X	C CAP.	0.01μF 50V K	

△ Symbol No.	Part No.	Part Name	Description	Local
CAPACITOR				
C1610	QETN1HM-106Z	E CAP.	10μF 50V M	
C1611	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1612	QETN1HM-106Z	E CAP.	10μF 50V M	
C1613	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1615	QETN1HM-106Z	E CAP.	10μF 50V M	
C1616	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1617	QETN1HM-106Z	E CAP.	10μF 50V M	
C1619	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1620	QETN1HM-106Z	E CAP.	10μF 50V M	
C1621-22	NCB31HK-102X	C CAP.	1000pF 50V K	
C1623-24	NCF31AZ-105X	C CAP.	1μF 10V Z	
C1650	QEHR1HM-106Z	E CAP.	10μF 50V M	
C1651	QEHQ1HM-107	E CAP.	100μF 50V M	
C1652	QETN1HM-106Z	E CAP.	10μF 50V M	
C1659-61	NCF21HZ-224X	C CAP.	0.22μF 50V Z	
C1662	QETN1HM-106Z	E CAP.	10μF 50V M	
C1663	NCF21HZ-224X	C CAP.	0.22μF 50V Z	
C1665	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1666-67	NCB31HK-222X	C CAP.	2200pF 50V K	
C1668-69	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1670	NCB31HK-223X	C CAP.	0.022μF 50V K	
C1671	QETN1CM-476Z	E CAP.	47μF 16V M	
C1672	NCB31HK-473X	C CAP.	0.047μF 50V K	
C1673	QETN1CM-336Z	E CAP.	33μF 16V M	
C1674	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1675	NCB31HK-473X	C CAP.	0.047μF 50V K	
C1676	NCB31HK-223X	C CAP.	0.022μF 50V K	
C1681-82	QETN1CM-227Z	E CAP.	220μF 16V M	
C1683	QETN1CM-336Z	E CAP.	33μF 16V M	
C1702	QETN1HM-106Z	E CAP.	10μF 50V M	
C1703-04	NDC31HJ-220X	C CAP.	22pF 50V J	
C1706	NCB21EK-224X	C CAP.	0.22μF 25V K	
C1707	QETN1CM-107Z	E CAP.	100μF 16V M	
C1709	QETN0JM-477Z	E CAP.	470μF 6.3V M	
C1710	QFV21HJ-224Z	MF CAP.	0.22μF 50V J	
C1711	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1712	QETN1CM-476Z	E CAP.	47μF 16V M	
C1713	QFV11HJ-104Z	TF CAP.	0.1μF 50V J	
C1720	QETN1HM-476Z	E CAP.	47μF 50V M	
C1725	NCB31HK-681X	C CAP.	680pF 50V K	
C1730-31	NCB21EK-224X	C CAP.	0.22μF 25V K	
C1732	QETN1CM-107Z	E CAP.	100μF 16V M	
C1733	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1734-35	NCB31HK-222X	C CAP.	2200pF 50V K	
C1736-37	QETN1HM-105Z	E CAP.	1μF 50V M	
C1738	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1739	NFV41CJ-104X	MPP CAP.	0.1μF 16V J	
C1740	QETN1HM-225Z	E CAP.	2.2μF 50V M	
C1741-42	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1743	QETN1CM-107Z	E CAP.	100μF 16V M	
C1744	NCB31HK-222X	C CAP.	2200pF 50V K	
C1745-47	NCB31EK-473X	C CAP.	0.047μF 25V K	
C1749	QETN1HM-106Z	E CAP.	10μF 50V M	
C1751-53	NCB21HK-104X	C CAP.	0.1μF 50V K	
C1801-04	QETN1HM-106Z	E CAP.	10μF 50V M	
C1805	QFLC1HJ-104Z	M CAP.	0.1μF 50V J	
C1807-08	NCF31AZ-105X	C CAP.	1μF 10V Z	
C1810	NCF31AZ-105X	C CAP.	1μF 10V Z	
C1811	QFLC1HJ-104Z	M CAP.	0.1μF 50V J	
C1812	NCF31AZ-105X	C CAP.	1μF 10V Z	
C1813	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1814	QFLC1HJ-104Z	M CAP.	0.1μF 50V J	
C1815	NCF31AZ-105X	C CAP.	1μF 10V Z	
C1817	NCF31AZ-105X	C CAP.	1μF 10V Z	
C1819	QFLC1HJ-104Z	M CAP.	0.1μF 50V J	
C1820-21	NCF31AZ-105X	C CAP.	1μF 10V Z	
C1822	QETN1AM-477Z	E CAP.	470μF 10V M	
C1823-24	QETN1CM-107Z	E CAP.	100μF 16V M	
C1825	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1826	QFLC1HJ-104Z	M CAP.	0.1μF 50V J	
C1827	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1829-31	NCB31HK-103X	C CAP.	0.01μF 50V K	

△ Symbol No.	Part No.	Part Name	Description	Local
CAPACITOR				
C1834	NDC31HJ-181X	C CAP.	180pF 50V J	
△ C1902	QFZ9073-104	MF CAP.	0.1μF	
C1903-05	QCZ9015-102Z	C CAP.	1000pF 250V Z	
C1907	QEZ0371-337	E CAP.	330μF 400V M	
C1909	QCZ0325-821	C CAP.	820pF 2000V K	
C1910	NDC31HJ-471X	C CAP.	470pF 50V J	
C1911	QETN1HM-476Z	E CAP.	47μF 50V M	
C1916	QETN1EM-476Z	E CAP.	47μF 25V M	
C1917	QCB32HK-181Z	C CAP.	180pF 500V K	
C1918	QCB32HK-103	C CAP.	0.01μF 500V K	
C1919	QCZ0325-391	C CAP.	390pF 2000V K	
C1952	QCB32HK-471Z	C CAP.	470pF 500V K	
C1953	QEHQ1VM-228	E CAP.	2200μF 35V M	
C1955	QCB32HK-471Z	C CAP.	470pF 500V K	
C1956	QETN1VM-107Z	E CAP.	100μF 35V M	
C1957	QCB31HK-471Z	C CAP.	470pF 50V K	
C1958	QEHR1CM-108Z	E CAP.	1000μF 16V M	
C1959	QCZ0364-561	C CAP.	560pF	
C1960	QEZ0203-227	E CAP.	220μF 160V M	
C1962	QETN1HM-106Z	E CAP.	10μF 50V M	
C1963	QETN1CM-477Z	E CAP.	470μF 16V M	
C1964	QETN1CM-476Z	E CAP.	47μF 16V M	
C1965	QETN1VM-476Z	E CAP.	47μF 35V M	
C1966	QETN1CM-107Z	E CAP.	100μF 16V M	
C1968	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1972	QETN1HM-476Z	E CAP.	47μF 50V M	
C1974	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1975	QETN1CM-227Z	E CAP.	220μF 16V M	
C1977	QETN1EM-476Z	E CAP.	47μF 25V M	
C1978	NCB21HK-104X	C CAP.	0.1μF 50V K	
C1980	QETN1CM-107Z	E CAP.	100μF 16V M	
C1981	NCB31HK-102X	C CAP.	1000pF 50V K	
C1982	QETN1CM-476Z	E CAP.	47μF 16V M	
C1983	QETN1CM-107Z	E CAP.	100μF 16V M	
△ C1991	QCZ9079-102	C CAP.	1000pF 250V M	
△ C1992-93	QCZ9079-471	C CAP.	470pF 250V K	
TRANSFORMER				
T1521	QQR1229-001	DRIVE TRANSF.		
△ T1551	QQH0077-001	H.V.TRANSF.		
T1561	QQR1153-001	DEF.TRANSF.		
△ T1901	QQS0110-001	SWICH.TRANSF.		
COIL				
L1001-02	QQL244K-8R2Z	COIL	8.2μH	K
L1101-02	QQL244K-5R6Z	COIL	5.6μH	K
L1103	QQL244K-100Z	COIL	10μH	K
L1104	QQL244K-180Z	COIL	18μH	K
L1301	QQL244K-221Z	COIL	220μH	K
L1401	QQL26AK-220Z	COIL	22μH	K
L1480	QQR1138-001	CHOKE COIL		
L1522	QQLZ028-501	CHOKE COIL		
L1523	QQR1243-001	LINEARITY COIL		
L1541	QQL244K-220Z	COIL	22μH	K
L1561	QQLZ028-272	CHOKE COIL		
L1601	QQL244K-4R7Z	COIL	4.7μH	K
L1701-02	QQL244K-100Z	COIL	10μH	K
L1731	QRN143J-0R0X	C R	0.0Ω	1/4W J
L1951	QQLZ034-460	CHOKE COIL		
L1953	QQL244J-5R6Z	COIL	5.6μH	J
L1954	QQL26AK-820Z	COIL	82μH	K
DIODE				
D1101	DAN235K-X	SI.DIODE		
D1401	RGP10J-5025-T3	SI.DIODE		
D1402	MTZJ75-T2	ZENER DIODE		
D1405	1N4003-T2	SI.DIODE		
D1408	MA111-X	SI.DIODE		
D1480	MTZJ4.3A-T2	ZENER DIODE		
D1521	RH3G-F1	SI.DIODE		
D1522	31DF6N-FC5	DIODE		

△ Symbol No.	Part No.	Part Name	Description	Local
CAPACITOR				
D1523	RGP10J-5025-T3	SI.DIODE		
D1541	RGP10J-5025-T3	SI.DIODE		
D1550	MA111-X	SI.DIODE		
D1551	EU2-T3	SI.DIODE		
D1553	RGP10J-5025-T3	SI.DIODE		
D1554	RGP10J-5025-T3	SI.DIODE		
D1561-62	ES1F-LFG2	SI.DIODE		
D1592	MA3075/H-X	ZENER DIODE		
D1652-53	MA3330/L-X	ZENER DIODE		
D1682	MA111-X	SI.DIODE	0.0Ω 1/16W J	
D1683	NRSA63J-0R0X	MG R		
D1702	MA3020-X	ZENER DIODE		
D1730-33	MA111-X	SI.DIODE		
D1801-02	MA3120/M-X	ZENER DIODE		
D1901	GSIB460	DIODE		
D1902	QQR1214-001Y	FERRITE BEADS		
D1903	CE41433-001Z	BEADS CORE		
D1906	MTZJ27B-T2	ZENER DIODE		
D1907	MTZJ33B-T2	ZENER DIODE		
D1908	MA3200/M-X	ZENER DIODE		
D1909	MA111-X	SI.DIODE		
D1910	MA3075/H-X	ZENER DIODE		
D1911	RGP10J-5025-T3	SI.DIODE		
D1912	RGP10J-5025-T3	SI.DIODE		
D1913	RGP10M-5010-T3	SI.DIODE		
D1914	1SS133-T2	SI.DIODE		
D1915	MA3068/M-X	ZENER DIODE		
D1916	MTZJ15B-T2	ZENER DIODE		
D1950	RGP10J-5025-T3	SI.DIODE		
D1952	ERC30-02L38	SI.DIODE		
D1953	RGP10J-5025-T3	SI.DIODE		
D1954	RU30A-F1	SI.DIODE		
D1955	1SR35-400A-T2	SI.DIODE		
D1956	31DF6N-FC5	DIODE		
D1958	MTZJ5.1A-T2	ZENER DIODE		
D1960	MA111-X	SI.DIODE		
D1964	MA3330/L-X	ZENER DIODE		
D1966	MA3039/H-X	ZENER DIODE		
D1968-69	MA111-X	SI.DIODE		
D1970	MTZJ9.1B-T2	ZENER DIODE		
D1971	MA111-X	SI.DIODE		
TRANSISTOR				
Q1101	2SC5083/L-P-T	SI.TRANSISTOR		
Q1102-03	DTC124EKA-X	DIGI.TRANSISTOR		
Q1104	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1105-06	DTC124EKA-X	DIGI.TRANSISTOR		
Q1107	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1108	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1109	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1110	DTC124EKA-X	DIGI.TRANSISTOR		
Q1111	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1150	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1301-02	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1303	DTC124EKA-X	DIGI.TRANSISTOR		
Q1304	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1480	2SD1408/OY/-LB	SI.TRANSISTOR		
Q1521	2SC2655/Y/-T	SI.TRANSISTOR		
Q1522	2SD2634-YD	SI.TRANSISTOR		
Q1574	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1575	2SC4686A	SI.TRANSISTOR		
Q1591	2SA1208/ST/Z1-T	SI.TRANSISTOR		
Q1592	DTC124EKA-X	DIGI.TRANSISTOR		
Q1660-61	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1683-84	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1685-86	DTC323TK-X	DIGI.TRANSISTOR		
Q1687	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1701-02	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1703	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1720	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1801-02	DTC323TK-X	DIGI.TRANSISTOR		
Q1804	2SC1740S/QR/-T	SI.TRANSISTOR		

△ Symbol No.	Part No.	Part Name	Description	Local
TRANSISTOR				
Q1833	QETN1HM-226Z	E CAP	22μF 50V M	
Q1860	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1861-62	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1901	2SC3852A	SI.TRANSISTOR		
Q1902-03	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1951	2SA1013/RO/-T	SI.TRANSISTOR		
Q1952-54	2SC2412K/QR/-X	SI.TRANSISTOR		
IC				
IC1301	TDA9181T/N1-X	I.C(MONO-ANA)		
IC1401	LA78041	I.C(MONO-ANA)		
IC1461	JLC1562BF-X	I.C(DIGI-MOS)		
IC1480	UPC358G2-XE	I.C(MONO-ANA)		
IC1601	MSP3415D-QG-B3X	I.C(MONO-ANA)		
IC1650	AN5277	I.C(MONO-ANA)		
IC1665	BA4558F-X	I.C(MONO-ANA)		
IC1701	TDA9365N13S0455	I.C(μ-COMP)		
IC1702	AT24C08-34LS	I.C(MEMORY-OTH)	(SERVICE)	
IC1801	MM1492AF	I.C(MONO-ANA)		
IC1901	STR-F6456S/F7	I.C(HYBRID)		
IC1951	SE135N	I.C(HYBRID)		
IC1972	L88M33T-X	I.C(MONO-ANA)		
IC1973	BA17812T	I.C(MONO-ANA)		
IC1974	BA51W12ST-V5	I.C(MONO-ANA)		
OTHERS				
CF1103	TPSH6.0MB	CERAMIC FILTER		
CF1104	TPS5.5MW	CERAMIC FILTER		
CF1105	TPS6.5MB	CERAMIC FILTER		
CF1106	QAX0639-001Z	CERAMIC FILTER		
△ CP1650	ICP-N50-Y	I.C.PROTECT		
△ CP1951	ICP-N75-Y	I.C.PROTECT		
△ CP1953	ICP-N38-Y	I.C.PROTECT		
J1801	QNN0349-001	PIN JACK		
J1802	QNN0349-002	PIN JACK		
J1803	QNN0348-001	PIN JACK		
J1804	QNN0349-001	PIN JACK		
K1301	CE41433-001Z	BEADS CORE		
K1902	QQR1214-001Y	FERRITE BEADS		
K1903	CE41433-001Z	BEADS CORE		
K1904	CE42050-001Z	CORE		
K1951	QQR1214-001Y	FERRITE BEADS		
K1953-55	QQR1214-001Y	FERRITE BEADS		
LC1601	CE42482-103Y	EMI FILTER		
△ LF1901	QQR1035-002	LINE FILTER		
△ PC1901	PC123F2	I.C(PH.COUPLER)		
△ RY1901	QSK0061-001	RELAY		
SF1101	QAX0663-001	SAW FILTER		
SF1102	QAX0594-001	SAW FILTER		
TH1901	QAD0134-4R5	P.THERMISTOR		
TU1001	QAU0185-004	TUNER		
W1010	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1071	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1239	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1257	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1260	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1306-07	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1309	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1321-22	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1325-26	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1330	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1333	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1339-40	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1347	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1355	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1379	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1386	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1395	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1397	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1402-03	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1408	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1418	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	

△ Symbol No.	Part No.	Part Name	Description	Local
OTHERS				
W1423	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1426-27	QRE141J-0R0Y	C R	0.0Ω 1/4W	J
X1601	CE42546-001Z	CRYSTAL		
X1701	QAX0688-001	CRYSTAL		
Y1004	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
Y1602	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J

CRT SOCKET PW BOARD ASS'Y (SCH-3002A-H2)

△ Symbol No.	Part No.	Part Name	Description	Local
RESISTOR				
R3101	NRSA63J-682X	MG R	6.8kΩ 1/16W	J
R3102	NRSA63J-102X	MG R	1kΩ 1/16W	J
R3103	NRSA63J-153X	MG R	15kΩ 1/16W	J
R3104	NRSA63J-682X	MG R	6.8kΩ 1/16W	J
R3105	NRSA63J-102X	MG R	1kΩ 1/16W	J
R3106	NRSA63J-272X	MG R	2.7kΩ 1/16W	J
R3107	NRSA63J-682X	MG R	6.8kΩ 1/16W	J
R3108	NRSA63J-102X	MG R	1kΩ 1/16W	J
R3109	NRSA63J-562X	MG R	5.6kΩ 1/16W	J
R3125	NRSA63J-222X	MG R	2.2kΩ 1/16W	J
R3126	QRE121J-393Y	C R	39kΩ 1/2W	J
R3128	QRE141J-473Y	C R	47kΩ 1/4W	J
R3129	QRE141J-223Y	C R	22kΩ 1/4W	J
R3142	NRSA63J-101X	MG R	100Ω 1/16W	J
R3150	QRZ0107-152Z	C R	1.5kΩ 1/2W	K
R3152	NRSA63J-101X	MG R	100Ω 1/16W	J
R3160	NRSA63J-101X	MG R	100Ω 1/16W	J
R3166	QRZ0107-152Z	C R	1.5kΩ 1/2W	K
R3169	QVP0038-206	V R	20MΩ	
R3170	QRZ0107-474Z	C R	470kΩ 1/2W	K
R3171	QRZ0107-152Z	C R	1.5kΩ 1/2W	K
R3172	NRSA63J-101X	MG R	100Ω 1/16W	J
△ R3175	QRZ9021-1R0	F R	1Ω 1W	J
R3176	QRE121J-123Y	C R	12kΩ 1/2W	J
R3211	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
R3212	NRSA63J-153X	MG R	15kΩ 1/16W	J
R3213	NRSA63J-222X	MG R	2.2kΩ 1/16W	J
R3214	NRSA63J-152X	MG R	1.5kΩ 1/16W	J
R3215	NRSA63J-680X	MG R	68Ω 1/16W	J
R3216	NRSA63J-221X	MG R	220Ω 1/16W	J
△ R3217	QRJ146J-100X	C R	10Ω 1/4W	J
R3221-22	NRSA63J-470X	MG R	47Ω 1/16W	J
R3224	NRSA63J-122X	MG R	1.2kΩ 1/16W	J
R3225-26	QRE121J-563Y	C R	56kΩ 1/2W	J
R3227	NRSA63J-122X	MG R	1.2kΩ 1/16W	J
R3228	NRSA63J-390X	MG R	39Ω 1/16W	J
R3229-30	QRE121J-2R7Y	C R	2.7Ω 1/2W	J
R3231	NRSA63J-390X	MG R	39Ω 1/16W	J
R3232	QRE121J-121Y	C R	120Ω 1/2W	J
R3233	QRL029J-391	OM R	390Ω 2W	J
R3251	NRSA63J-822X	MG R	8.2kΩ 1/16W	J
R3252	NRSA63J-222X	MG R	2.2kΩ 1/16W	J
R3253	NRSA63J-101X	MG R	100Ω 1/16W	J
R3254	NRSA63J-563X	MG R	56kΩ 1/16W	J
R3255	NRSA63J-223X	MG R	22kΩ 1/16W	J
R3256	NRSA63J-681X	MG R	680Ω 1/16W	J
R3257	NRSA63J-102X	MG R	1kΩ 1/16W	J
R3258	NRSA63J-182X	MG R	1.8kΩ 1/16W	J
R3259	NRSA63J-102X	MG R	1kΩ 1/16W	J
R3260	NRSA63J-271X	MG R	270Ω 1/16W	J
R3261-63	NRSA63J-101X	MG R	100Ω 1/16W	J
R3264	NRSA63J-222X	MG R	2.2kΩ 1/16W	J
R3265	NRSA63J-102X	MG R	1kΩ 1/16W	J

△ Symbol No.	Part No.	Part Name	Description	Local
RESISTOR				
R3266	NRSA63J-103X	MG R	10kΩ 1/16W	J
R3267	NRSA63J-102X	MG R	1kΩ 1/16W	J
R3268	NRSA63J-222X	MG R	2.2kΩ 1/16W	J
R3269	NRSA63J-102X	MG R	1kΩ 1/16W	J
R3270	NRSA63J-103X	MG R	10kΩ 1/16W	J
R3271	NRSA63J-102X	MG R	1kΩ 1/16W	J
R3272	NRSA63J-222X	MG R	2.2kΩ 1/16W	J
R3273	NRSA63J-102X	MG R	1kΩ 1/16W	J
R3274	NRSA63J-103X	MG R	10kΩ 1/16W	J
R3275	NRSA63J-102X	MG R	1kΩ 1/16W	J

CAPACITOR

C3101	QETN1CM-477Z	E CAP.	470μF	16V	M
C3102	QETN2EM-475Z	E CAP.	4.7μF	250V	M
C3107	QETM2EM-336	E CAP.	33μF	250V	M
C3109	QCZ0131-472	C CAP.	4700pF	2000V	K
C3110	QCZ0131-222	C CAP.	2200pF	2000V	K
C3121	QETN1HM-225Z	E CAP.	2.2μF	50V	M
C3123	QFK62EK-104Z	MM CAP.	0.1μF	250V	K
C3204	NDC31HJ-561X	C CAP.	560pF	50V	J
C3205	QETN1HM-335Z	E CAP.	3.3μF	50V	M
C3206	QETN1HM-106Z	E CAP.	10μF	50V	M
C3209	QETN1CM-107Z	E CAP.	100μF	16V	M
C3212	QCB32HK-472Z	C CAP.	4700pF	500V	K
C3213	NDC31HJ-561X	C CAP.	560pF	50V	J
C3214	QETN2CM-106Z	E CAP.	10μF	160V	M
C3215	QCB32HK-472Z	C CAP.	4700pF	500V	K
C3216	QETN2CM-106Z	E CAP.	10μF	160V	M
C3217-18	QETN1AM-107Z	E CAP.	100μF	10V	M
C3219	QETN1AM-337Z	E CAP.	330μF	10V	M
C3251	QENC1HM-105Z	BP E CAP.	1μF	50V	M
C3252	NDC31HJ-151X	C CAP.	150pF	50V	J
C3253	NDC31HJ-560X	C CAP.	56pF	50V	J
C3255	NCB31HK-103X	C CAP.	0.01μF	50V	K
C3264-66	QETN1AM-107Z	E CAP.	100μF	10V	M

COIL

L3121	QQL244J-5R6Z	COIL	5.6μH		J
L3251	QQL244K-150Z	COIL	15μH		K

DIODE

D3108	MA3075/H/-X	ZENER DIODE			
D3109	MA3051/H/-X	ZENER DIODE			
D3110	MA1111-X	SI.DIODE			
D3111	MA3051/H/-X	ZENER DIODE			
D3112	MA1111-X	SI.DIODE			
D3113	MA3051/H/-X	ZENER DIODE			
D3114	MA1111-X	SI.DIODE			
D3115	RGP10J-5025-T3	SI.DIODE			
D3116	RGP10J-5025-T3	SI.DIODE			
D3117	RGP10J-5025-T3	SI.DIODE			
D3121-23	1N4003-T2	SI.DIODE			
D3124	MA1111-X	SI.DIODE			
D3125	MTZJ75-T2	ZENER DIODE			
D3201-02	NRSA63J-0R0X	MG R	0.0Ω	1/16W	J
D3203	RGP10J-5025-T3	SI.DIODE			
D3204	RGP10J-5025-T3	SI.DIODE			

TRANSISTOR

Q3101-03	2SC2412K/QR/-X	SI.TRANSISTOR			
Q3121	2SC4212Z1/	SI.TRANSISTOR			
Q3122	2SA1037AK/QR/-X	SI.TRANSISTOR			
Q3204-05	2SC1740S/QR/-T	SI.TRANSISTOR			
Q3206	2SA933AS/QR/-T	SI.TRANSISTOR			
Q3209	2SA1964/DE/	SI.TRANSISTOR			
Q3210	2SC5248/DE/	SI.TRANSISTOR			
Q3251	2SA1037AK/QR/-X	SI.TRANSISTOR			
Q3252	2SC2412K/QR/-X	SI.TRANSISTOR			
Q3253	2SA1037AK/QR/-X	SI.TRANSISTOR			
Q3261-63	2SA1037AK/QR/-X	SI.TRANSISTOR			

△ Symbol No.	Part No.	Part Name	Description	Local
TRANSISTOR				
Q3264-66	2SC2412K/QR/-X	SI.TRANSISTOR		
IC				
IC3101	TDA6107Q/N2	I.C(MONO-ANA)		
OTHERS				
DL3261-63	CE41925-001	DELAY LINE		
△ FR3201	QRZ9021-561	F R	560Ω	1W J
K3201-04	CE41492-001Z	CHOKE COIL		
SG3101-03	QAF0006-501	ARRESTER		
SG3104	QAF0041-272	ARRESTER		
△ SK3001	CE42446-001	C.R.T.SOCKET		

FRONT CONTROL PW BOARD ASS'Y (SCH-8002A-H2)

△ Symbol No.	Part No.	Part Name	Description	Local
RESISTOR				
R8482	NRSA63J-124X	MG R	120kΩ	1/16W J
R8483	NRSA63J-683X	MG R	68kΩ	1/16W J
R8484-85	NRSA63J-562X	MG R	5.6kΩ	1/16W J
R8486	NRSA63J-333X	MG R	33kΩ	1/16W J
R8487	NRSA63J-332X	MG R	3.3kΩ	1/16W J
R8488	NRSA63J-154X	MG R	150kΩ	1/16W J
R8489	NRSA63J-104X	MG R	100kΩ	1/16W J
R8491-92	NRSA63J-0R0X	MG R	0.0Ω	1/16W J
R8495	NRSA63J-152X	MG R	1.5kΩ	1/16W J
R8497	NRSA63J-562X	MG R	5.6kΩ	1/16W J
R8498	QRE141J-0R0Y	C R	0.0Ω	1/4W J
R8499	QRE121J-561Y	C R	560Ω	1/2W J
R8801	NRSA63J-332X	MG R	3.3kΩ	1/16W J
R8802	NRSA63J-392X	MG R	3.9kΩ	1/16W J
R8803	NRSA63J-682X	MG R	6.8kΩ	1/16W J
R8805	NRSA63J-682X	MG R	6.8kΩ	1/16W J
R8807	NRSA63J-181X	MG R	180Ω	1/16W J
R8808	NRSA63J-221X	MG R	220Ω	1/16W J
R8809	NRSA63J-331X	MG R	330Ω	1/16W J
R8810	NRSA63J-471X	MG R	470Ω	1/16W J
R8811	NRSA63J-821X	MG R	820Ω	1/16W J
R8812	NRSA63J-122X	MG R	1.2kΩ	1/16W J
R8813	NRSA63J-471X	MG R	470Ω	1/16W J
R8814	NRSA63J-750X	MG R	75Ω	1/16W J
R8815-16	QRE121J-271Y	C R	270Ω	1/2W J
R8817-18	NRSA63J-102X	MG R	1kΩ	1/16W J
R8819	NRSA63J-272X	MG R	2.7kΩ	1/16W J
R8826	NRSA63J-0R0X	MG R	0.0Ω	1/16W J
R8830-31	NRSA63J-222X	MG R	2.2kΩ	1/16W J
△ R8901	QRZ0111-474	C R	470kΩ	1/2W K
CAPACITOR				
C8481-84	NCB21EK-224X	C CAP.	0.22μF	25V K
C8485	QETN1EM-476Z	E CAP.	47μF	25V M
C8487	QFLC1HJ-103Z	M CAP.	0.01μF	50V J
C8660-61	QETM1VM-108	E CAP.	1000μF	35V M
C8801	QETN1HM-106Z	E CAP.	10μF	50V M
C8802	QETN1CM-107Z	E CAP.	100μF	16V M
C8803	NCB31CK-104X	C CAP.	0.1μF	16V K
C8815	QETN1CM-107Z	E CAP.	100μF	16V M
△ C8901	QFZ9073-224	MF CAP.	0.22μF	
COIL				
L8401	QQL244K-820Z	COIL	82μH	K

△ Symbol No.	Part No.	Part Name	Description	Local
DIODE				
D8601-02	MTZJ75-T2	ZENER DIODE		
D8801	MA111-X	SI.DIODE		
D8802	P1241-04	C.D.S.		
D8803	SLR-342VR-T16	L.E.D.		
TRANSISTOR				
Q8481	2SC2412K/QR/-X	SI.TRANSISTOR		
Q8801	2SA1037AK/QR/-X	SI.TRANSISTOR		
IC				
IC8481	LA6515	I.C(MONO-ANA)		
IC8801	GP1U281Q	IFR DETECT UNIT		
OTHERS				
	CM35921-005-H	CDS HOLDER		
	CM36626-B01-H	L.E.D.HOLDER		
△ F8901	QMF51E2-4R0J4	FUSE		
FC8901	CEMG002-001Z	FUSE CLIP		
J8302	QNN0279-003	PIN JACK		
J8303	QNN0279-002	PIN JACK		
J8304	QNN0279-001	PIN JACK		
J8801	QNS0155-001	JACK		
△ LF8901	QQR1035-002	LINE FILTER		
S8801	QSW0619-003Z	PUSH SWITCH		CH-
S8802	QSW0619-003Z	PUSH SWITCH		CH+
S8803	QSW0619-003Z	PUSH SWITCH		MENU
S8804	QSW0619-003Z	PUSH SWITCH		TV/VIDEO
S8805	QSW0619-003Z	PUSH SWITCH		VOL-
S8806	QSW0619-003Z	PUSH SWITCH		VOL+
△ S8901	QSW0750-001	PUSH SWITCH		POWER
△ VA8901	QAF0052-621	VARISTOR		
Y8401	NRSA63J-0R0X	MG R	0.0Ω	1/16W J

DIFFERENCE PARTS LIST BETWEEN AV-34LS, AV-34LS-AU AND AV-34LH

In the DIFFERENCE PARTS LIST BETWEEN AV-34LS, AV-34LS-AU and AV-34LH, only difference points between these models are written. For other parts not mentioned in the list, please refer to the PARTS LIST(P42 – P47) for the AV-34LS.

DIFFERENCE PARTS LIST

△	Symbol No.	Part No.			Part Name
		AV-34LS	AV-34LS-AU	AV-34LH	
		SCH-1007A-H2	SCH-1037A-H2	SCH-1036A-H2	MAIN PWB
	IC1701	TDA9365N13S0455	←	TDA9386N12S0450	IC
	R1801	—	NRSA63J-750X (75Ω, 1/16W, J)	—	MG R
	R1802	—	NRSA63J-750X (75Ω, 1/16W, J)	—	MG R
	R1817	—	NRSA63J-101X (100Ω, 1/16W, J)	—	MG R
	R1819	—	NRSA63J-101X (100Ω, 1/16W, J)	—	MG R
	C1806	—	QFLC1HJ-104Z (0.1μF, 50V, J)	—	M CAP.
	C1809	—	NCB31HK-103X (0.01μF, 50V, K)	—	C CAP.
	J1801	QNN0349-001	QNZ0454-001	QNN0349-001	PIN JACK

PRINTED WIRING BOARD PARTS LIST (AV-34LX)

MAIN PW BOARD ASS'Y(SCH-1008A-H2)

△	Symbol No.	Part No.	Part Name	Description	Local	△	Symbol No.	Part No.	Part Name	Description	Local
RESISTOR						RESISTOR					
	R1001-02	NRSA63J-221X	MG R	220Ω 1/16W J			R1492	NRSA63J-822X	MG R	8.2kΩ 1/16W J	
	R1003	NRSA63J-392X	MG R	3.9kΩ 1/16W J			R1493	QRE121J-223Y	C R	22kΩ 1/2W J	
	R1004	NRSA63J-221X	MG R	220Ω 1/16W J			R1494	QRL03EJ-330X	OM R	33Ω 3W J	
	R1006	NRSA63J-273X	MG R	27kΩ 1/16W J			R1521	NRSA63J-101X	MG R	100Ω 1/16W J	
	R1101	NRSA63J-100X	MG R	10Ω 1/16W J			R1522	NRSA63J-102X	MG R	1kΩ 1/16W J	
	R1102	NRSA63J-682X	MG R	6.8kΩ 1/16W J			R1523	QRL03EJ-181X	OM R	180Ω 3W J	
	R1103	NRSA63J-272X	MG R	2.7kΩ 1/16W J			R1524	QRL03EJ-181X	OM R	180Ω 3W J	
	R1104	NRSA63J-181X	MG R	180Ω 1/16W J			R1526	QRL029J-271	OM R	270Ω 2W J	
	R1105	NRSA63J-100X	MG R	10Ω 1/16W J			R1527	QRL03EJ-103X	OM R	10kΩ 3W J	
	R1106	NRSA63J-101X	MG R	100Ω 1/16W J			R1528-29	QRX029J-3R3	MF R	3.3Ω 2W J	
	R1107	NRSA63J-472X	MG R	4.7kΩ 1/16W J			R1531	NRSA63J-182X	MG R	1.8kΩ 1/16W J	
	R1108-09	NRSA63J-222X	MG R	2.2kΩ 1/16W J		△	R1532	QRZ9017-4R7	F R	4.7Ω 1/4W J	
	R1111	NRSA63J-102X	MG R	1kΩ 1/16W J			R1540	QRZ9011-4R7	F R	4.7Ω 1/2W J	
	R1112	NRSA63J-103X	MG R	10kΩ 1/16W J			R1541	QRE121J-124Y	C R	120kΩ 1/2W J	
	R1113	NRSA63J-271X	MG R	270Ω 1/16W J			R1542	QRE121J-104Y	C R	100kΩ 1/2W J	
	R1114	NRSA63J-821X	MG R	820Ω 1/16W J			R1543	QRE121J-471Y	C R	470Ω 1/2W J	
	R1115	NRSA63J-181X	MG R	180Ω 1/16W J			R1545	QRE121J-220Y	C R	22Ω 1/2W J	
	R1117	NRSA63J-102X	MG R	1kΩ 1/16W J			R1546	QRE121J-822Y	C R	8.2kΩ 1/2W J	
	R1119	NRSA63J-102X	MG R	1kΩ 1/16W J			R1561	QRL02EJ-220X	OM R	22Ω 2W J	
	R1120	NRSA63J-471X	MG R	470Ω 1/16W J			R1562	QRE121J-123Y	C R	12kΩ 1/2W J	
	R1130	NRSA63J-472X	MG R	4.7kΩ 1/16W J			R1563	QRZ0056-103Z	COMPR	10kΩ 1/2W K	
	R1131	NRSA63J-471X	MG R	470Ω 1/16W J			R1564-68	QRE121J-184Y	C R	180kΩ 1/2W J	
	R1132	NRSA63J-222X	MG R	2.2kΩ 1/16W J			R1571	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
	R1133	NRSA63J-152X	MG R	1.5kΩ 1/16W J			R1578	NRSA63J-102X	MG R	1kΩ 1/16W J	
	R1134	NRSA63J-182X	MG R	1.8kΩ 1/16W J			R1580	NRSA63J-392X	MG R	3.9kΩ 1/16W J	
	R1135	NRSA63J-561X	MG R	560Ω 1/16W J			R1581	NRSA63J-183X	MG R	18kΩ 1/16W J	
	R1136	NRSA63J-472X	MG R	4.7kΩ 1/16W J			R1582	NRSA63J-392X	MG R	3.9kΩ 1/16W J	
	R1137	NRSA63J-103X	MG R	10kΩ 1/16W J			R1583	NRSA63J-183X	MG R	18kΩ 1/16W J	
	R1138	NRSA63J-561X	MG R	560Ω 1/16W J			R1584	NRSA63J-152X	MG R	1.5kΩ 1/16W J	
	R1139	NRSA63J-222X	MG R	2.2kΩ 1/16W J			R1591	QRA14CF-1202Y	MF R	12kΩ 1/4W F	
	R1140	NRSA63J-152X	MG R	1.5kΩ 1/16W J			R1592	QRZ0221-2R2	UNF R	2.2Ω	
	R1141	NRSA63J-182X	MG R	1.8kΩ 1/16W J			R1593	NRSA02F-332X	MG R	3.3kΩ 1/10W F	
	R1142	NRSA63J-561X	MG R	560Ω 1/16W J			R1594	QRE121J-183Y	C R	18kΩ 1/2W J	
	R1143	NRSA63J-471X	MG R	470Ω 1/16W J			R1595	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
	R1144	NRSA63J-220X	MG R	22Ω 1/16W J			R1621-22	NRSA63J-101X	MG R	100Ω 1/16W J	
	R1145	NRSA63J-821X	MG R	820Ω 1/16W J			R1626	NRSA63J-472X	MG R	4.7kΩ 1/16W J	
	R1146	NRSA63J-103X	MG R	10kΩ 1/16W J			R1627	NRSA63J-224X	MG R	220kΩ 1/16W J	
	R1147	NRSA63J-101X	MG R	100Ω 1/16W J			R1628	NRSA63J-104X	MG R	100kΩ 1/16W J	
	R1148	NRSA63J-332X	MG R	3.3kΩ 1/16W J			R1629	NRSA63J-153X	MG R	15kΩ 1/16W J	
	R1149	QRE141J-122Y	C R	1.2kΩ 1/4W J			R1630	NRSA63J-273X	MG R	27kΩ 1/16W J	
	R1301-02	NRSA63J-222X	MG R	2.2kΩ 1/16W J			R1631	NRSA63J-473X	MG R	47kΩ 1/16W J	
	R1303	NRSA63J-562X	MG R	5.6kΩ 1/16W J			R1632-33	NRSA63J-103X	MG R	10kΩ 1/16W J	
	R1304-05	NRSA63J-222X	MG R	2.2kΩ 1/16W J			R1640	QRE141J-102Y	C R	1kΩ 1/4W J	
	R1306	NRSA63J-562X	MG R	5.6kΩ 1/16W J			R1650-51	NRSA63J-392X	MG R	3.9kΩ 1/16W J	
	R1307	NRSA63J-103X	MG R	10kΩ 1/16W J			R1654-55	NRSA63J-392X	MG R	3.9kΩ 1/16W J	
	R1308	NRSA63J-101X	MG R	100Ω 1/16W J			R1658-59	QRE121J-2R2Y	C R	2.2Ω 1/2W J	
	R1309	NRSA63J-104X	MG R	100kΩ 1/16W J			R1660	NRSA63J-103X	MG R	10kΩ 1/16W J	
	R1310	NRSA63J-473X	MG R	47kΩ 1/16W J			R1661	NRSA63J-683X	MG R	68kΩ 1/16W J	
	R1311	NRSA63J-123X	MG R	12kΩ 1/16W J			R1662	NRSA63J-333X	MG R	33kΩ 1/16W J	
	R1401	NRSA63J-224X	MG R	220kΩ 1/16W J			R1663	NRSA63J-103X	MG R	10kΩ 1/16W J	
	R1403	NRSA63J-0R0X	MG R	0.0Ω 1/16W J			R1664	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
	R1405	NRSA63J-682X	MG R	6.8kΩ 1/16W J			R1688	NRSA63J-273X	MG R	27kΩ 1/16W J	
	R1406	NRSA63J-472X	MG R	4.7kΩ 1/16W J			R1690	NRSA63J-104X	MG R	100kΩ 1/16W J	
	R1408	NRSA63J-682X	MG R	6.8kΩ 1/16W J			R1692	NRSA63J-104X	MG R	100kΩ 1/16W J	
	R1410	NRSA63J-472X	MG R	4.7kΩ 1/16W J			R1693	NRSA63J-103X	MG R	10kΩ 1/16W J	
	R1411	QRG01GJ-221	OM R	220Ω 1W J			R1694	NRSA63J-472X	MG R	4.7kΩ 1/16W J	
	R1412	QRE121J-1R0Y	C R	1.0Ω 1/2W J			R1695	NRSA63J-562X	MG R	5.6kΩ 1/16W J	
	R1413	QRX01GJ-1R2	MF R	1.2Ω 1W J			R1696	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
	R1414	QRE121J-1R8Y	C R	1.8Ω 1/2W J			R1701	NRSA63J-103X	MG R	10kΩ 1/16W J	
	R1425	NRSA63J-683X	MG R	68kΩ 1/16W J			R1702-03	NRSA63J-101X	MG R	100Ω 1/16W J	
	R1478-79	NRSA63J-101X	MG R	100Ω 1/16W J			R1704-05	NRSA63J-102X	MG R	1kΩ 1/16W J	
	R1480	QRE121J-681Y	C R	680Ω 1/2W J			R1706	NRSA63J-682X	MG R	6.8kΩ 1/16W J	
	R1481	NRSA63J-223X	MG R	22kΩ 1/16W J			R1707-10	NRSA63J-472X	MG R	4.7kΩ 1/16W J	
	R1482	NRSA63J-562X	MG R	5.6kΩ 1/16W J			R1711-14	NRSA63J-101X	MG R	100Ω 1/16W J	
	R1483	NRSA63J-823X	MG R	82kΩ 1/16W J			R1715-17	NRSA63J-103X	MG R	10kΩ 1/16W J	
	R1484	NRSA63J-562X	MG R	5.6kΩ 1/16W J			R1718-19	NRSA63J-221X	MG R	220Ω 1/16W J	
	R1485	NRSA63J-123X	MG R	12kΩ 1/16W J			R1720	NRSA63J-102X	MG R	1kΩ 1/16W J	
	R1486	NRSA63J-272X	MG R	2.7kΩ 1/16W J			R1721-24	NRSA63J-221X	MG R	220Ω 1/16W J	
	R1487	NRSA63J-333X	MG R	33kΩ 1/16W J			R1725	NRSA63J-103X	MG R	10kΩ 1/16W J	
	R1489	NRSA63J-122X	MG R	1.2kΩ 1/16W J			R1726	NRSA63J-472X	MG R	4.7kΩ 1/16W J	
	R1490	NRSA63J-102X	MG R	1kΩ 1/16W J			R1727	NRSA63J-104X	MG R	100kΩ 1/16W J	
	R1491	NRSA63J-562X	MG R	5.6kΩ 1/16W J			R1728	NRSA63J-103X	MG R	10kΩ 1/16W J	

△ Symbol No.	Part No.	Part Name	Description	Local
RESISTOR				
R1730	NRSA63J-223X	MG R	22kΩ 1/16W J	
R1731	NRSA63J-101X	MG R	100Ω 1/16W J	
R1732	NRSA02F-393X	MF R	39kΩ 2W F	
R1733	NRSA63J-273X	MG R	27kΩ 1/16W J	
R1734	NRSA63J-391X	MG R	390Ω 1/16W J	
R1735	NRSA63J-104X	MG R	100kΩ 1/16W J	
R1736	NRSA63J-333X	MG R	33kΩ 1/16W J	
R1737	NRSA63J-272X	MG R	2.7kΩ 1/16W J	
R1738	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1739-41	NRSA63J-101X	MG R	100Ω 1/16W J	
R1742	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
R1744	NRSA63J-561X	MG R	560Ω 1/16W J	
R1745	NRSA63J-105X	MG R	1MΩ 1/16W J	
R1746	NRSA63J-333X	MG R	33kΩ 1/16W J	
R1747	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1748	QRE141J-394Y	C R	390kΩ 1/4W J	
R1749	QRE141J-334Y	C R	330kΩ 1/4W J	
R1755-56	NRSA63J-101X	MG R	100Ω 1/16W J	
R1757-58	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1803	NRSA63J-333X	MG R	33kΩ 1/16W J	
R1804-07	NRSA63J-750X	MG R	75Ω 1/16W J	
R1808	NRSA63J-823X	MG R	82kΩ 1/16W J	
R1809	NRSA63J-391X	MG R	390Ω 1/16W J	
R1810	NRSA63J-823X	MG R	82kΩ 1/16W J	
R1811	NRSA63J-391X	MG R	390Ω 1/16W J	
R1812	NRSA63J-104X	MG R	100kΩ 1/16W J	
R1813	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1815	NRSA63J-101X	MG R	100Ω 1/16W J	
R1818	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1820	NRSA63J-101X	MG R	100Ω 1/16W J	
R1821	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1823	NRSA63J-101X	MG R	100Ω 1/16W J	
R1824	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1826	NRSA63J-101X	MG R	100Ω 1/16W J	
R1830-31	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1832	QRE141J-391Y	C R	390Ω 1/4W J	
R1833	NRSA63J-331X	MG R	330Ω 1/16W J	
R1834-35	NRSA63J-562X	MG R	5.6kΩ 1/16W J	
R1836	NRSA63J-750X	MG R	75Ω 1/16W J	
R1837	NRSA63J-101X	MG R	100Ω 1/16W J	
R1838	QRK126J-121X	C R	120Ω 1/2W J	
R1839-40	QRE121J-221Y	C R	220Ω 1/2W J	
R1841-42	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
R1843	NRSA63J-821X	MG R	820Ω 1/16W J	
R1844	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1845	NRSA63J-102X	MG R	1kΩ 1/16W J	
R1846	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1847	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1848	NRSA63J-221X	MG R	220Ω 1/16W J	
R1849	NRSA63J-471X	MG R	470Ω 1/16W J	
R1880	NRSA63J-202X	MG R	2kΩ 1/16W J	
R1881	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1882	NRSA63J-181X	MG R	180Ω 1/16W J	
R1883	NRSA63J-471X	MG R	470Ω 1/16W J	
R1902	QRF154K-2R2	UNF R	2.2Ω K	
R1903	QRL039J-473	OM R	47kΩ 3W J	
R1904	QRE121J-681Y	C R	680Ω 1/2W J	
R1905	QRM034J-R10	MP R	0.1Ω 3W J	
R1908	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1909	QRE121J-274Y	C R	270kΩ 1/2W J	
R1911	QRE121J-472Y	C R	4.7kΩ 1/2W J	
R1912	QRE121J-222Y	C R	2.2kΩ 1/2W J	
△ R1913	QRZ9017-4R7	F R	4.7Ω 1/4W J	
R1914	QRL039J-473	OM R	47kΩ 3W J	
R1915	QRE121J-394Y	C R	390kΩ 1/2W J	
R1916	QRE121J-332Y	C R	3.3kΩ 1/2W J	
R1917	NRSA63J-101X	MG R	100Ω 1/16W J	
R1918	NRSA63J-224X	MG R	220kΩ 1/16W J	
R1919	NRSA63J-104X	MG R	100kΩ 1/16W J	
R1920	NRSA63J-473X	MG R	47kΩ 1/16W J	
R1921	QRE121J-563Y	C R	56kΩ 1/2W J	
R1951	QRE121J-223Y	C R	22kΩ 1/2W J	

△ Symbol No.	Part No.	Part Name	Description	Local
RESISTOR				
R1952	NRSA63J-222X	MG R	2.2kΩ 1/16W J	
R1953	QRE121J-152Y	C R	1.5kΩ 1/2W J	
R1955	QRG01GJ-470	OM R	47Ω 1W J	
R1957	QRE121J-5R6Y	C R	5.6Ω 1/2W J	
R1958	QRL039J-820	OM R	82Ω 3W J	
R1959	QRE121J-820Y	C R	82Ω 1/2W J	
R1960	NRSA63J-391X	MG R	390Ω 1/16W J	
R1961	QRL02EJ-223X	OM R	22kΩ 2W J	
R1963	QRE121J-332Y	C R	3.3kΩ 1/2W J	
R1964	NRSA63J-103X	MG R	10kΩ 1/16W J	
R1965	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
R1966	NRSA63J-682X	MG R	6.8kΩ 1/16W J	
R1967	NRSA63J-473X	MG R	47kΩ 1/16W J	
R1969	QRT02EJ-2R7X	MF R	2.7Ω 2W J	
R1970	NRSA63J-153X	MG R	15kΩ 1/16W J	
R1971	NRSA63J-183X	MG R	18kΩ 1/16W J	
△ R1991	QRZ0057-825	C R	8.2MΩ 1W J	
CAPACITOR				
C1001	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1002	QETN1HM-106Z	E CAP.	10μF 50V M	
C1003	QFV71HJ-104Z	MF CAP.	0.1μF 50V J	
C1004	QETN1CM-477Z	E CAP.	470μF 16V M	
C1005	NCB31HK-222X	C CAP.	2200pF 50V K	
C1006	QETN1CM-336Z	E CAP.	33μF 16V M	
C1007	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1101-05	NCB31HK-472X	C CAP.	4700pF 50V K	
C1106-07	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1109	QETN1HM-106Z	E CAP.	10μF 50V M	
C1130-32	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1133	QETN1CM-107Z	E CAP.	100μF 16V M	
C1134	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1135	QETN1EM-476Z	E CAP.	47μF 25V M	
C1136-38	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1140-42	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1143	QETN1HM-106Z	E CAP.	10μF 50V M	
C1144	NCB31HK-223X	C CAP.	0.022μF 50V K	
C1301-02	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1304-05	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1306	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1307	NDC31HJ-330X	C CAP.	33pF 50V J	
C1308	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1401	QETN1HM-105Z	E CAP.	1μF 50V M	
C1402	QCB31HK-682Z	C CAP.	6800pF 50V K	
C1403	QEHR1VM-107Z	E CAP.	100μF 35V M	
C1411-12	NCF21HZ-334X	C CAP.	0.33μF 50V Z	
C1413	QFLC2AJ-563Z	M CAP.	0.056μF 100V J	
C1422	QEHR1VM-108Z	E CAP.	1000μF 35V M	
C1471	QETN1HM-106Z	E CAP.	10μF 50V M	
C1480	QETN1HM-106Z	E CAP.	10μF 50V M	
C1483	QEZ0195-475Z	E CAP.	4.7μF 50V M	
C1485	QETN1HM-226Z	E CAP.	22μF 50V M	
C1521	QETN1VM-476Z	E CAP.	47μF 35V M	
C1522	QFLC1HJ-332Z	M CAP.	3300pF 50V J	
C1523	QFLC1HJ-223Z	M CAP.	0.022μF 50V J	
C1524	QFZ0200-372	MPP CAP.	3700pF 1.5kVH±3%	
C1525	QFZ0200-123	MPP CAP.	0.012μF 1.5kVH±3%	
C1526	QFP32JJ-223	PP CAP.	0.022μF 630V J	
C1527	QFZ0199-184	MPP CAP.	0.18μF 250V J	
C1528	QFZ0199-204	MPP CAP.	0.2μF 250V J	
C1529	QENC2AM-225Z	BP E CAP.	2.2μF 100V M	
C1530	QCB32HK-561Z	C CAP.	560pF 500V K	
C1531	QEHR1EM-108Z	E CAP.	1000μF 25V M	
C1532	QCB32HK-561Z	C CAP.	560pF 500V K	
C1533	QEHR1EM-108Z	E CAP.	1000μF 25V M	
C1534	QCB32HK-561Z	C CAP.	560pF 500V K	
C1536	QFLC1HJ-103Z	M CAP.	0.01μF 50V J	
C1540	QFV71HJ-104Z	MF CAP.	0.1μF 50V J	
C1541	QETN2EM-106Z	E CAP.	10μF 250V M	
C1542	QFZ0128-473	MPP CAP.	0.047μF 400V±3%	
C1550	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1561	QFV11HJ-683Z	TF CAP.	0.068μF 50V J	

△ Symbol No.	Part No.	Part Name	Description	Local	△ Symbol No.	Part No.	Part Name	Description	Local
CAPACITOR					CAPACITOR				
C1563-64	QCZ0122-471	C CAP.	470pF 2000V K		C1819	QFLC1HJ-104Z	M CAP.	0.1μF 50V J	
C1565	QFZ0122-682	MPP CAP.	6800pF 1.8kVH ±3%		C1820-21	NCF31AZ-105X	C CAP.	1μF 10V Z	
C1566	QFZ0200-113	MPP CAP.	0.011μF 1.5kVH ±3%		C1822	QETN1AM-477Z	E CAP.	470μF 10V M	
C1571	QETN1CM-476Z	E CAP.	47μF 16V M		C1823-24	QETN1CM-107Z	E CAP.	100μF 16V M	
C1575	QETN1EM-476Z	E CAP.	47μF 25V M		C1825	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1591	QETN1AM-107Z	E CAP.	100μF 10V M		C1826	QFLC1HJ-104Z	M CAP.	0.1μF 50V J	
C1592	QETM2CM-227	E CAP.	220μF 160V M		C1827	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1593	QETN1EM-476Z	E CAP.	47μF 25V M		C1829-31	NCB31HK-103X	C CAP.	0.01μF 50V K	
C1610	QETN1CM-228Z	E CAP.	2200μF 16V M		C1834	NDC31HJ-181X	C CAP.	180pF 50V J	
C1625	QETN1HM-106Z	E CAP.	10μF 50V M		△ C1902	QFZ9073-104	MF CAP.	0.1μF	
C1626	QETN1CM-107Z	E CAP.	100μF 16V M		C1903-05	QCZ9015-102Z	C CAP.	1000pF 250V Z	
C1629	QETN1HM-475Z	E CAP.	4.7μF 50V M		C1907	QE20371-337	E CAP.	330μF 400V M	
C1630	NDC31HJ-471X	C CAP.	470pF 50V J		C1909	QCZ0325-821	C CAP.	820pF 2000V K	
C1631	NCB31EK-333X	C CAP.	0.033μF 25V K		C1910	NDC31HJ-471X	C CAP.	470pF 50V J	
C1634	QETN1HM-106Z	E CAP.	10μF 50V M		C1911	QETN1HM-476Z	E CAP.	47μF 50V M	
C1636-37	QETN1HM-105Z	E CAP.	1μF 50V M		C1916	QETN1EM-476Z	E CAP.	47μF 25V M	
C1638	NCB31EK-333X	C CAP.	0.033μF 25V K		C1917	QCB32HK-181Z	C CAP.	180pF 500V K	
C1639	NDC31HJ-471X	C CAP.	470pF 50V J		C1918	QCB32HK-103	C CAP.	0.01μF 500V K	
C1640	QETN1HM-475Z	E CAP.	4.7μF 50V M		C1919	QCZ0325-391	C CAP.	390pF 2000V K	
C1641	QETN1CM-107Z	E CAP.	100μF 16V M		C1952	QCB32HK-471Z	C CAP.	470pF 500V K	
C1642	NCB31CK-104X	C CAP.	0.1μF 16V K		C1953	QEHQ1VM-228	E CAP.	2200μF 35V M	
C1643	NCB31HK-562X	C CAP.	5600pF 50V K		C1955	QCB32HK-471Z	C CAP.	470pF 500V K	
C1644	QETN1HM-475Z	E CAP.	4.7μF 50V M		C1956	QETN1VM-107Z	E CAP.	100μF 35V M	
C1645-46	QETN1HM-106Z	E CAP.	10μF 50V M		C1957	QCB31HK-471Z	C CAP.	470pF 50V K	
C1647	NCB31EK-393X	C CAP.	0.039μF 25V K		C1958	QEH1CM-108Z	E CAP.	1000μF 16V M	
C1648	NCB31HK-223X	C CAP.	0.022μF 50V K		C1959	QCZ0364-561	C CAP.	560pF	
C1650	QEH1HM-106Z	E CAP.	10μF 50V M		C1960	QE20203-227	E CAP.	220μF 160V M	
C1651	QEHQ1HM-107	E CAP.	100μF 50V M		C1962	QETN1HM-106Z	E CAP.	10μF 50V M	
C1652	QETN1HM-106Z	E CAP.	10μF 50V M		C1963	QETN1CM-477Z	E CAP.	470μF 16V M	
C1659-61	NCF21HZ-224X	C CAP.	0.22μF 50V Z		C1964	QETN1CM-476Z	E CAP.	47μF 16V M	
C1662	QETN1HM-106Z	E CAP.	10μF 50V M		C1965	QETN1VM-476Z	E CAP.	47μF 35V M	
C1663	NCF21HZ-224X	C CAP.	0.22μF 50V Z		C1966	QETN1CM-107Z	E CAP.	100μF 16V M	
C1665	NCF31AZ-105X	C CAP.	1μF 10V Z		C1968	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1669	NCF31AZ-105X	C CAP.	1μF 10V Z		C1972	QETN1HM-476Z	E CAP.	47μF 50V M	
C1681-82	QETN1CM-227Z	E CAP.	220μF 16V M		C1974	NCB31CK-104X	C CAP.	0.1μF 16V K	
C1683	QETN1CM-336Z	E CAP.	33μF 16V M		C1975	QETN1CM-227Z	E CAP.	220μF 16V M	
C1684	QETN1HM-106Z	E CAP.	10μF 50V M		C1977	QETN1EM-476Z	E CAP.	47μF 25V M	
C1702	QETN1HM-106Z	E CAP.	10μF 50V M		C1978	NCB21HK-104X	C CAP.	0.1μF 50V K	
C1703-04	NDC31HJ-220X	C CAP.	22pF 50V J		C1980	QETN1CM-107Z	E CAP.	100μF 16V M	
C1706	NCB21EK-224X	C CAP.	0.22μF 25V K		C1981	NCB31HK-102X	C CAP.	1000pF 50V K	
C1707	QETN1CM-107Z	E CAP.	100μF 16V M		C1982	QETN1CM-476Z	E CAP.	47μF 16V M	
C1709	QETN0JM-477Z	E CAP.	470μF 6.3V M		C1983	QETN1CM-107Z	E CAP.	100μF 16V M	
C1710	QFV21HJ-224Z	MF CAP.	0.22μF 50V J		△ C1991	QCZ9079-102	C CAP.	1000pF 250V M	
C1711	NCB31CK-104X	C CAP.	0.1μF 16V K		△ C1992-93	QCZ9079-471	C CAP.	470pF 250V K	
C1712	QETN1CM-476Z	E CAP.	47μF 16V M		TRANSFORMER				
C1713	QFV11HJ-104Z	TF CAP.	0.1μF 50V J		T1521	QQR1229-001	DRIVE TRANSF.		
C1720	QETN1HM-476Z	E CAP.	47μF 50V M		△ T1551	QQH0077-001	H.V.TRANSF.		
C1725	NCB31HK-681X	C CAP.	680pF 50V K		T1561	QQR1153-001	DEF.TRANSF.		
C1730-31	NCB21EK-224X	C CAP.	0.22μF 25V K		△ T1901	QQS0110-001	SWICH.TRANSF.		
C1732	QETN1CM-107Z	E CAP.	100μF 16V M		COIL				
C1733	NCB31CK-104X	C CAP.	0.1μF 16V K		L1001-02	QQL244K-8R2Z	COIL	8.2μH	K
C1734-35	NCB31HK-222X	C CAP.	2200pF 50V K		L1101-02	QQL244J-5R6Z	COIL	5.6μH	J
C1736-37	QETN1HM-105Z	E CAP.	1μF 50V M		L1103	QQL244K-100Z	COIL	10μH	K
C1738	NCB31CK-104X	C CAP.	0.1μF 16V K		L1104	QQL244K-180Z	COIL	18μH	K
C1739	NFV41CJ-104X	MPP CAP.	0.1μF 16V J		L1301	QQL244K-221Z	COIL	220μH	K
C1740	QETN1HM-225Z	E CAP.	2.2μF 50V M		L1401	QQL26AK-220Z	COIL	22μH	K
C1741-42	NCB31CK-104X	C CAP.	0.1μF 16V K		L1480	QQR1138-001	CHOKE COIL		
C1743	QETN1CM-107Z	E CAP.	100μF 16V M		L1522	QQLZ028-501	CHOKE COIL		
C1744	NCB31HK-222X	C CAP.	2200pF 50V K		L1523	QQR1243-001	LINEARITY COIL		
C1745-47	NCB31EK-473X	C CAP.	0.047μF 25V K		L1541	QQL244K-220Z	COIL	22μH	K
C1749	QETN1HM-106Z	E CAP.	10μF 50V M		L1561	QQLZ028-272	CHOKE COIL		
C1751-53	NCB21HK-104X	C CAP.	0.1μF 50V K		L1701-02	QQL244K-100Z	COIL	10μH	K
C1801-04	QETN1HM-106Z	E CAP.	10μF 50V M		L1731	QRN143J-0R0X	C R	0.0Ω	1/4W J
C1805	QFLC1HJ-104Z	M CAP.	0.1μF 50V J		L1951	QQLZ034-460	CHOKE COIL		
C1807-08	NCF31AZ-105X	C CAP.	1μF 10V Z		L1953	QQL244J-5R6Z	COIL	5.6μH	J
C1810	NCF31AZ-105X	C CAP.	1μF 10V Z		L1954	QQL26AK-820Z	COIL	82μH	K
C1811	QFLC1HJ-104Z	M CAP.	0.1μF 50V J		DIODE				
C1812	NCF31AZ-105X	C CAP.	1μF 10V Z		D1101	1SS85-T2	SI.DIODE		
C1813	NCB31HK-103X	C CAP.	0.01μF 50V K		D1401	RG10J-5025-T3	SI.DIODE		
C1814	QFLC1HJ-104Z	M CAP.	0.1μF 50V J						
C1815	NCF31AZ-105X	C CAP.	1μF 10V Z						
C1817	NCF31AZ-105X	C CAP.	1μF 10V Z						

△ Symbol No.	Part No.	Part Name	Description	Local
DIODE				
D1402	MTZJ75-T2	ZENER DIODE		
D1405	1N4003-T2	SI.DIODE		
D1408	MA111-X	SI.DIODE		
D1480	MTZJ4.3A-T2	ZENER DIODE		
D1521	RH3G-F1	SI.DIODE		
D1522	31DF6N-FC5	DIODE		
D1523	RGP10J-5025-T3	SI.DIODE		
D1541	RGP10J-5025-T3	SI.DIODE		
D1550	MA111-X	SI.DIODE		
D1551	EU2-T3	SI.DIODE		
D1553	RGP10J-5025-T3	SI.DIODE		
D1554	RGP10J-5025-T3	SI.DIODE		
D1561-62	ES1F-LFG2	SI.DIODE		
D1592	MA3075/H-X	ZENER DIODE		
D1652-53	MA3330/L-X	ZENER DIODE		
D1682	MA111-X	SI.DIODE		
D1683	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
D1702	MA3020-X	ZENER DIODE		
D1730-33	MA111-X	SI.DIODE		
D1801-02	MA3120/M-X	ZENER DIODE		
D1901	GSIB460	DIODE		
D1902	MTZJ33B-T2	ZENER DIODE		
D1903	1SS133-T2	SI.DIODE		
D1906	MTZJ27B-T2	ZENER DIODE		
D1907	MTZJ33B-T2	ZENER DIODE		
D1908	MA3200/M-X	ZENER DIODE		
D1909	MA111-X	SI.DIODE		
D1910	MA3075/H-X	ZENER DIODE		
D1911	RGP10J-5025-T3	SI.DIODE		
D1912	RGP10J-5025-T3	SI.DIODE		
D1913	RGP10M-5010-T3	SI.DIODE		
D1914	1SS133-T2	SI.DIODE		
D1915	MA3068/M-X	ZENER DIODE		
D1916	MTZJ15B-T2	ZENER DIODE		
D1950	RGP10J-5025-T3	SI.DIODE		
D1952	ERC30-02L38	SI.DIODE		
D1953	RGP10J-5025-T3	SI.DIODE		
D1954	RU30A-F1	SI.DIODE		
D1955	1SR35-400A-T2	SI.DIODE		
D1956	31DF6N-FC5	DIODE		
D1958	MTZJ5.1A-T2	ZENER DIODE		
D1960	MA111-X	SI.DIODE		
D1964	MA3330/L-X	ZENER DIODE		
D1966	MA3039/H-X	ZENER DIODE		
D1968-69	MA111-X	SI.DIODE		
D1970	MTZJ9.1B-T2	ZENER DIODE		
D1971	MA111-X	SI.DIODE		
TRANSISTOR				
Q1101	2SC5083/L-P/T	SI.TRANSISTOR		
Q1102	DTC124EKA-X	DIGI.TRANSISTOR		
Q1104	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1105-06	DTC124EKA-X	DIGI.TRANSISTOR		
Q1107	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1108	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1109	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1110	DTC124EKA-X	DIGI.TRANSISTOR		
Q1111	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1130	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1131	DTC124EKA-X	DIGI.TRANSISTOR		
Q1132	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1133	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1134-35	DTC124EKA-X	DIGI.TRANSISTOR		
Q1136-37	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1301-02	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1303	DTC124EKA-X	DIGI.TRANSISTOR		
Q1304	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1480	2SD1408/OY/-LB	SI.TRANSISTOR		
Q1521	2SC2655/Y/-T	SI.TRANSISTOR		
Q1522	2SD2634-YD	SI.TRANSISTOR		
Q1574	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1575	2SC4686A	SI.TRANSISTOR		
Q1591	2SA1208/ST/Z1-T	SI.TRANSISTOR		

△ Symbol No.	Part No.	Part Name	Description	Local
TRANSISTOR				
Q1592	DTC124EKA-X	DIGI.TRANSISTOR		
Q1660-61	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1683-84	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1685-86	DTC323TK-X	DIGI.TRANSISTOR		
Q1687	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1688	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1701-02	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1703	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1720	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1801-02	DTC323TK-X	DIGI.TRANSISTOR		
Q1803	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1804	2SC1740S/QR/-T	SI.TRANSISTOR		
Q1833	QETN1HM-226Z	E CAP.	22μF 50V M	
Q1860	2SC2412K/QR/-X	SI.TRANSISTOR		
Q1861-62	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1901	2SC3852A	SI.TRANSISTOR		
Q1902-03	2SA1037AK/QR/-X	SI.TRANSISTOR		
Q1951	2SA1013/RO/-T	SI.TRANSISTOR		
Q1952-54	2SC2412K/QR/-X	SI.TRANSISTOR		
IC				
IC1130	M52342SP	I.C(MONO-ANA)		
IC1301	TDA9181T/N1-X	I.C(MONO-ANA)		
IC1401	LA78041	I.C(MONO-ANA)		
IC1461	JLC1562BF-X	I.C(DIGI-MOS)		
IC1480	UPC358G2-XE	I.C(MONO-ANA)		
IC1602	BH3865S	I.C		
IC1650	AN5277	I.C(MONO-ANA)		
IC1701	TDA9386N12S0432	I.C		
IC1702	AT24C08-34LS	I.C(MEMORY-OTH)	(SERVICE)	
IC1801	MM1492AF	I.C(MONO-ANA)		
IC1901	STR-F6456S/F7	I.C(HYBRID)		
IC1951	SE135N	I.C(HYBRID)		
IC1972	L88M33T-X	I.C(MONO-ANA)		
IC1973	BA17812T	I.C(MONO-ANA)		
IC1974	BA51W12ST-V5	I.C(MONO-ANA)		
OTHERS				
CF1103	TPSH6.0MB	CERAMIC FILTER		
CF1104	TPS5.5MW	CERAMIC FILTER		
CF1105	TPS6.5MB	CERAMIC FILTER		
CF1106	QAX0639-001Z	CERAMIC FILTER		
CF1130	QAX0642-001Z	CERAMIC FILTER		
CF1140	QAX0336-001	CERAMIC FILTER		
CF1141	QAX0337-001	CERAMIC FILTER		
CF1142	QAX0338-001	CERAMIC FILTER		
△ CP1650	ICP-N50-Y	I.C.PROTECT		
△ CP1951	ICP-N75-Y	I.C.PROTECT		
△ CP1953	ICP-N38-Y	I.C.PROTECT		
J1801	QNN0349-001	PIN JACK		
J1802	QNN0349-002	PIN JACK		
J1803	QNN0348-001	PIN JACK		
J1804	QNN0349-001	PIN JACK		
K1301	CE41433-001Z	BEADS CORE		
K1902	QQR1214-001Y	FERRITE BEADS		
K1903	CE41433-001Z	BEADS CORE		
K1904	CE42050-001Z	CORE		
K1951	QQR1214-001Y	FERRITE BEADS		
K1953-55	QQR1214-001Y	FERRITE BEADS		
△ LF1901	QQR1035-002	LINE FILTER		
△ PC1901	PC123F2	I.C(PH.COUPLER)		
△ RY1901	QSK0061-001	RELAY		
SF1101	QAX0325-001	SAW FILTER		
SF1102	QAX0594-001	SAW FILTER		
TH1901	QAD0134-4R5	P.THERMISTOR		
TU1001	QAU0185-003	TUNER		
W1010	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1071	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1239	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	
W1257	NRSA63J-0R0X	MG R	0.0Ω 1/16W J	

△ Symbol No.	Part No.	Part Name	Description	Local
OTHERS				
W1260	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1273	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1304	QRE121J-221Y	C R	220Ω 1/2W	J
W1306-07	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1309	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1310	QRE121J-221Y	C R	220Ω 1/2W	J
W1321-22	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1325-26	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1330	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1333	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1339-40	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1347	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1355	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1366	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1379	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1386	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1395	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1397	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1402-03	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1408	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1418	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1423	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
W1426-27	QRE141J-0R0Y	C R	0.0Ω 1/4W	J
X1701	QAX0688-001	CRYSTAL		
Y1001-02	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
Y1130	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J
Y1601	NRSA63J-0R0X	MG R	0.0Ω 1/16W	J

CRT SOCKET PW BOARD ASS'Y (SCH-3002A-H2)

Parts list is the same as for AV-34LS. Refer to page 46.

FRONT CONTROL PW BOARD ASS'Y (SCH-8002A-H2)

Parts list is the same as for AV-34LS. Refer to page 47.

DIFFERENCE PARTS LIST BETWEEN AV-34LX, AV-34LX-A AND AV-3408TEE

In the DIFFERENCE PARTS LIST BETWEEN AV-34LX, AV-34LX-A and AV-3408TEE, only difference points between these models are written. For other parts not mentioned in the list, please refer to the PARTS LIST(P49 – P53) for the AV-34LX.

DIFFERENCE PARTS LIST

△	Symbol No.	Part No.			Part Name
		AV-34LX	AV-34LX-A	AV-3408TEE	
		SCH-1008A-H2	←	SCH-1038A-H2	MAIN PWB
	IC1701	TDA9386N12S0450	←	TDA9365N13S0455	IC

REMOTE CONTROL UNIT PARTS LIST

RM-C352-1C [AV-34LS, AV-34LS-AU]


RM-C353-1C [AV-34LH]

RM-C357-1C [AV-34LX, AV-34LX-A]

RM-C355-1C [AV-3408TEE]

△	Ref. No.	Part No.	Part Name	Description	Local
		31392340128	BATTERY COVER		

PACKING



PACKING PARTS LIST

△ Ref.No.	Part No.	Part Name	Description	Local
1	CP30967-006-H	POLY BAG		
2	GG10144-001A-H	P CASE		
3	LC11084-002A-H	CUSHION ASSY		
4	RM-C352-1C	RC HAND UNIT	[AV-34LS,AV-34LS-AU]	
4	RM-C353-1C	RC HAND UNIT	[AV-34LH]	
4	RM-C355-1C	RC HAND UNIT	[AV-3408TEE]	
4	RM-C357-1C	RC HAND UNIT	[AV-34LX,AV-34LX-A]	
5	GG20012-001A-H	CORNER LABEL	(X2)	
△ 6	CP30966-001-H	POLY BAG		
△ 7	LC10935-001B-H	INST BOOK	[AV-34LS,AV-34LH,AV-34LS-AU,AV-34LX,AV-34LX-A]	
△ 7	LC1006-001B-H	INST BOOK	[AV-34LH]	
△ 7	LC11007-001A-H	INST BOOK	[AV-3408TEE]	
8	BT-56001-2	WARRANTY CARD	[AV-34LS-AU]	
8	BT-54012-2	WARRANTY CARD	[AV-3408TEE]	
9	BT-56002-2	S CENTRE LIST	[AV-34LS-AU]	
△ 10	LC10937-001A-H	DIGEST MANUAL	[AV-34LX,AV-34LX-A]	
△ 11	QAM0055-001	CONVERSION PLUG	[AV-34LX-A]	
△ 12	LC10057-001A-H	INST SHEET	[AV-34LS,AV-34LS-AU]	
△ 12	LC10058-001A-H	INST SHEET	[AV-3408TEE]	
13	CM46966-002	STICKER	[AV-34LS-AU]	
14	CP30903-001	JOINT	(X4)	
15	LC30947-002A-H	CAUTION SHEET		
16	LC30946-001A-H	CRT PROTECTOR		